

	mesures corrigées à 11% d'O2 -IC 95%								Flux massique										Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	2.03	0.19	4.86	7.87	0.00	75.45	0.20	1.83	0.00	0.07	0.01	0.17	0.28	0.00	2.67	0.01	1.57	0.0001	1125
01:00	2.15	0.19	4.77	10.24	0.00	75.20	0.25	2.41	0.02	0.08	0.01	0.17	0.37	0.00	2.74	0.01	2.08	0.0008	1123
01:30	0.23	0.00	4.56	11.78	0.00	61.86	0.40	5.70	0.04	0.01	0.00	0.17	0.44	0.00	2.29	0.01	4.96	0.0015	1112
02:00	0.40	0.00	4.30	8.80	0.00	62.70	0.38	5.64	0.04	0.01	0.00	0.16	0.32	0.00	2.28	0.01	4.88	0.0015	1099
02:30	1.44	0.00	4.61	9.80	0.00	61.41	0.36	5.65	0.02	0.05	0.00	0.17	0.36	0.00	2.24	0.01	4.90	0.0006	1103
03:00	1.00	0.00	4.08	8.65	0.00	63.19	0.36	5.67	0.02	0.04	0.00	0.15	0.32	0.00	2.32	0.01	4.97	0.0007	1117
03:30	8.27	0.04	5.16	15.94	0.00	59.46	0.34	5.71	0.04	0.30	0.00	0.19	0.58	0.00	2.17	0.01	4.89	0.0015	1103
04:00	2.56	0.02	5.19	11.86	0.00	61.01	0.37	5.80	0.04	0.09	0.00	0.19	0.44	0.00	2.24	0.01	4.96	0.0015	1107
04:30	1.78	0.00	3.77	7.02	0.00	62.88	0.42	5.69	0.00	0.06	0.00	0.14	0.25	0.00	2.28	0.02	4.86	0.0001	1101
05:00	0.31	0.01	3.50	7.31	0.00	61.11	0.37	5.70	0.02	0.01	0.00	0.13	0.26	0.00	2.21	0.01	4.89	0.0008	1114
05:30	0.29	0.00	5.04	12.87	0.00	63.38	0.38	5.74	0.06	0.01	0.00	0.19	0.47	0.00	2.33	0.01	4.94	0.0021	1122
06:00	0.94	0.09	4.13	8.14	0.00	63.18	0.29	3.99	0.36	0.03	0.00	0.15	0.29	0.00	2.24	0.01	3.42	0.0126	1108
06:30	1.33	0.14	4.32	10.48	0.00	61.34	0.32	2.63	0.45	0.05	0.01	0.15	0.37	0.00	2.16	0.01	2.28	0.0157	1119
07:00	0.87	0.03	5.26	13.81	0.00	60.50	0.49	5.71	2.44	0.03	0.00	0.19	0.50	0.00	2.20	0.02	4.91	0.0888	1112
07:30	0.89	0.01	3.95	6.74	0.00	63.72	0.52	5.63	0.04	0.03	0.00	0.14	0.24	0.00	2.29	0.02	4.84	0.0014	1109
08:00	0.28	0.00	4.18	9.74	0.00	61.66	0.47	5.71	0.04	0.01	0.00	0.15	0.36	0.00	2.27	0.02	4.97	0.0015	1122
08:30	0.36	0.00	3.65	7.10	0.00	62.37	0.47	5.67	0.13	0.01	0.00	0.13	0.26	0.00	2.29	0.02	4.98	0.0049	1

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.