

Paramètre	mesures corrigées à 11% d'O2 -IC 95%								Flux massique										Process
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	2.48	0.30	4.79	11.65	0.00	61.61	0.21	2.29	0.00	0.10	0.01	0.18	0.45	0.00	2.38	0.01	2.09	0.0000	1111
01:00	3.20	0.25	5.05	10.55	0.00	61.05	0.18	2.94	0.00	0.12	0.01	0.19	0.41	0.00	2.35	0.01	2.69	0.0000	1101
01:30	2.76	0.25	6.51	14.99	0.00	61.64	0.19	2.58	0.00	0.11	0.01	0.25	0.59	0.00	2.41	0.01	2.35	0.0000	1099
02:00	2.08	0.23	6.74	14.02	0.00	59.96	0.14	1.95	0.00	0.08	0.01	0.26	0.55	0.00	2.34	0.01	1.77	0.0000	1094
02:30	2.41	0.21	4.23	5.37	0.00	63.72	0.22	2.25	0.12	0.09	0.01	0.16	0.21	0.00	2.48	0.01	2.05	0.0046	1110
03:00	2.28	0.23	3.66	4.42	0.00	64.21	0.17	2.06	0.00	0.09	0.01	0.14	0.17	0.00	2.43	0.01	1.88	0.0000	1109
03:30	2.77	0.33	3.83	5.77	0.00	62.22	0.19	2.57	0.00	0.11	0.01	0.15	0.22	0.00	2.42	0.01	2.34	0.0000	1122
04:00	2.23	0.48	5.29	9.74	0.00	60.59	0.13	2.07	0.00	0.09	0.02	0.21	0.38	0.00	2.36	0.01	1.89	0.0000	1121
04:30	2.49	0.40	4.18	6.01	0.01	61.04	0.24	2.29	0.00	0.10	0.02	0.16	0.23	0.00	2.35	0.01	2.09	0.0000	1132
05:00	1.98	0.44	6.80	13.79	0.00	64.51	0.22	1.84	0.00	0.08	0.02	0.26	0.54	0.00	2.51	0.01	1.68	0.0000	1126
05:30	19.61	0.37	9.66	22.24	0.00	49.56	0.20	18.21	0.00	0.76	0.01	0.37	0.86	0.00	1.92	0.01	16.56	0.0000	1084
06:00	2.39	0.39	9.53	17.19	0.00	60.01	0.20	2.25	0.00	0.09	0.01	0.37	0.67	0.00	2.33	0.01	2.03	0.0000	1107
06:30	1.28	0.17	3.34	4.80	0.00	61.79	0.30	3.80	0.04	0.05	0.01	0.13	0.19	0.00	2.47	0.01	3.47	0.0014	1113
07:00	0.81	0.06	4.65	13.45	0.00	61.10	0.45	5.90	0.00	0.03	0.00	0.19	0.54	0.00	2.46	0.02	5.39	0.0000	1103
07:30	1.01	0.31	7.56	18.63	0.00	61.88	0.45	5.92	0.00	0.04	0.01	0.30	0.75	0.00	2.49	0.02	5.40	0.0000	1098
08:00	0.39	0.29	4.61	9.15	0.00	60.48	0.43	5.90	0.00	0.02	0.01	0.19	0.37	0.00	2.44	0.02	5.38	0.0000	1095
08:30	0.32	0.20	3.52	8.40	0.00	63.25	0.45	6.08	0.15	0.01	0.01	0.14	0.34	0.00	2.57	0.02	5.47	0.0062	1

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.