

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	3.49	0.00	5.89	10.46	0.00	63.27	0.47	3.29	0.00	0.14	0.00	0.23	0.41	0.00	2.46	0.02	2.96	0.0000	1124
01:00	3.34	0.00	5.54	7.88	0.01	61.78	0.47	3.13	0.02	0.13	0.00	0.22	0.31	0.00	2.41	0.02	2.85	0.0009	1126
01:30	4.46	0.00	5.31	8.10	0.00	63.62	0.51	4.22	0.04	0.18	0.00	0.21	0.32	0.00	2.51	0.02	3.83	0.0016	113
02:00	3.22	0.00	4.98	8.29	0.00	61.64	0.50	2.99	0.04	0.13	0.00	0.19	0.32	0.00	2.39	0.02	2.73	0.0016	1124
02:30	3.91	0.00	4.55	6.09	0.00	62.34	0.47	3.57	0.00	0.15	0.00	0.17	0.23	0.00	2.38	0.02	3.26	0.0000	1113
03:00	3.41	0.00	5.22	8.33	0.00	62.44	0.50	3.18	0.02	0.13	0.00	0.20	0.33	0.00	2.44	0.02	2.90	0.0009	1127
03:30	1.98	0.00	5.35	8.28	0.00	62.15	0.52	1.84	0.06	0.08	0.00	0.21	0.32	0.00	2.38	0.02	1.66	0.0021	1112
04:00	2.07	0.00	4.67	6.26	0.00	60.75	0.44	1.90	0.04	0.08	0.00	0.18	0.24	0.00	2.29	0.02	1.70	0.0015	1112
04:30	2.06	0.00	4.87	8.49	0.00	58.91	0.38	1.92	0.01	0.08	0.00	0.18	0.31	0.00	2.17	0.01	1.65	0.0006	1097
05:00	0.78	0.00	5.51	8.94	0.00	61.97	0.40	1.71	0.03	0.03	0.00	0.20	0.33	0.00	2.28	0.01	0.61	0.0010	1106
05:30	1.43	0.00	4.02	4.24	0.00	64.19	0.37	1.33	0.04	0.05	0.00	0.15	0.16	0.00	2.36	0.01	1.14	0.0015	1122
06:00	1.59	0.00	4.78	6.26	0.00	62.14	0.39	1.51	0.04	0.06	0.00	0.18	0.24	0.00	2.38	0.02	1.33	0.0015	1128
06:30	1.91	0.00	4.63	5.39	0.01	61.67	0.47	2.71	0.00	0.07	0.00	0.17	0.20	0.00	2.33	0.02	2.41	0.0000	1125
07:00	0.31	0.12	6.01	6.93	0.01	62.53	0.44	6.03	0.02	0.01	0.00	0.24	0.27	0.00	2.48	0.02	5.42	0.0009	1124
07:30	0.87	0.12	4.29	3.43	0.00	61.89	0.45	6.01	0.04	0.03	0.00	0.17	0.14	0.00	2.45	0.02	5.39	0.0016	1126
08:00	2.00	0.20	4.24	3.43	0.02	61.77	0.44	6.01	0.04	0.08	0.01	0.17	0.14	0.00	2.45	0.02	5.43	0.0016	1134
08:30	0.99	0.19	4.29	4.76	0.02	61.16	0.43	6.01	0.00	0.04	0.01	0.17	0.19	0.00	2.42	0.02	5.43	0.0000	1118
09:00	0.71	0.21	3.96	5.35	0.02	61.01	0.45	6.03	0.02	0.03	0.01	0.16	0.21	0.00	2.40	0.02	5.40	0.0008	1115
09:30	1.04	0.18	4.43	8.51	0.02	61.90	0.46	6.04	0.04	0.04	0.01	0.17	0.33	0.00	2.39	0.02	5.30	0.0015	1115
10:00	0.36	0.14	5.04	9.40	0.01	61.03	0.48	6.18	0.04	0.01	0.01	0.20	0.37	0.00	2.39	0.02	5.37	0.0015	1114
10:30	0.37	0.22	4.08	7.37	0.01	58.17	0.47	6.04	0.01	0.01	0.01	0.16	0.28	0.00	2.21	0.02	5.21	0.0005	1108
11:00	0.95	0.13	4.72	10.11	0.00	61.84	0.45	4.90	0.03	0.04	0.00	0.18	0.38	0.00	2.32	0.02	4.15	0.0011	1109
11:30	13.53	0.14	4.83	12.15	0.00	63.18	0.38	12.69	0.04	0.49	0.00	0.17	0.44	0.00	2.28	0.01	10.66	0.0015	1106
12:00	1.05	0.00	4.42	9.66	0.00	61.92	0.37	0.97	0.04	0.04	0.00	0.16	0.35	0.00	2.27	0.01	0.83	0.0014	1117
12:30	1.59	0.00	5.50	12.67	0.01	62.29	0.43	1.51	0.04	0.06	0.00	0.21	0.48	0.00	2.37	0.02	1.32	0.0016	1127
13:00	1.20	0.00	5.39	11.52	0.01	62.45	0.41	1.13	0.04	0.05	0.00	0.20	0.43	0.00	2.34	0.02	0.98	0.0016	1114
13:30	1.30	0.00	5.02	11.08	0.00	64.18	0.40	1.22	0.04	0.05	0.00	0.19	0.42	0.00	2.42	0.02	1.07	0.0015	1111
14:00	1.69	0.00	4.61	9.68	0.01	61.54	0.38	1.56	0.04	0.06	0.00	0.17	0.36	0.00	2.32	0.01	1.39	0.0015	1119
14:30	1.75	0.00	4.70	8.17	0.01	62.21	0.49	1.58	0.07	0.07	0.00	0.18	0.31	0.00	2.34	0.02	1.44	0.0025	1128
15:00	2.23	0.00	5.71	14.51	0.01	61.90	0.44	2.07	0.08	0.09	0.00	0.22	0.56	0.00	2.39	0.02	1.87	0.0031	1119
15:30	2.79	0.00	2.05	1.56	0.00	62.93	0.38	2.48	0.04	0.10	0.00	0.07	0.06	0.00	2.29	0.01	2.22	0.0015	1097
16:00	2.88	0.00	3.20	10.82	0.00	60.44	0.43	2.63	0.04	0.11	0.00	0.12	0.40	0.00	2.25	0.02	2.34	0.0015	1105
16:30	3.43	0.00	4.91	15.35	0.00	62.02	0.45	3.16	0.00	0.13	0.00	0.19	0.58	0.00	2.34	0.02	2.82	0.0000	1106
17:00	2.40	0.00	9.16	19.92	0.00	63.18	0.45	2.19	0.02	0.09	0.00	0.34	0.75	0.00	2.37	0.02	1.96	0.0008	1112
17:30	2.27	0.00	4.92	10.26	0.00	60.65	0.49	2.08	0.04	0.08	0.00	0.18	0.38	0.00	2.24	0.02	1.83	0.0015	1116
18:00	3.27	0.00	4.19	10.71	0.00	62.29	0.37	3.00	0.04	0.12	0.00	0.15	0.39	0.00	2.29	0.01	2.62	0.0015	1125
18:30	2.35	0.00	5.12	16.03	0.00	61.76	0.47	3.23	0.00	0.09	0.00	0.19	0.60	0.00	2.30	0.02	2.83	0.0001	1129
19:00	0.69	0.11	5.13	15.49	0.00	60.55	0.47	6.02	0.02	0.03	0.00	0.19	0.59	0.00	2.30	0.02	5.20	0.0009	1126
19:30	0.89	0.13	5.14	10.68	0.00	62.67	0.47	6.05	0.04	0.03	0.01	0.19	0.40	0.00	2.37	0.02	5.17	0.0014	1134
20:00	0.28	0.15	4.77	13.56	0.00	61.32	0.47	6.15	0.04	0.01	0.01	0.18	0.52	0.00	2.37	0.02	5.28	0.0014	1137
20:30	0.32	0.15	4.51	9.28	0.00	62.34	0.46	6.06	0.00	0.01	0.01	0.17	0.35	0.00	2.33	0.02	5.12	0.0001	1128
21:00	1.07	0.17	3.83	8.67	0.00	62.42	0.49	6.14	0.02	0.04	0.01	0.15	0.33	0.00	2.40	0.02	5.26	0.0009	1151
21:30	0.39	0.16	3.63	8.54	0.00	60.24	0.47	6.09	0.04	0.01	0.01	0.14	0.33	0.00	2.32	0.02	5.27	0.0014	1139
22:00	0.49	0.16	3.92	7.56	0.00	61.60	0.49	6.07	0.04	0.02	0.01	0.15	0.29	0.00	2.38	0.02	5.28	0.0014	1138
22:30	1.28	0.18	4.44	12.59	0.00	61.00	0.50	6.05	0.01	0.05	0.01	0.17	0.49	0.00	2.37	0.02	5.31	0.0005	1142
23:00	0.20	0.24	4.70	11.38	0.00	62.08	0.49	6.02	0.03	0.01	0.01	0.18	0.44	0.00	2.38	0.02	5.24	0.0010	1127
23:30	0.36	0.44	4.38	9.06	0.01	62.14	0.48	6.09	0.04	0.01	0.02	0.17	0.36	0.00	2.44	0.02	5.36	0.0015	1143
00:00	1.76	0.48	4.12	8.64	0.01	61.85	0.50	6.04	0.04	0.07	0.02	0.16	0.34	0.00	2.41	0.02	5.36	0.0015	1142
Min	0,20	0,00	2,05	1,56	0,00	58,17	0,37	0,71	0,00	0,01	0,00	0,07	0,06	0,00	2,17	0,01	0,61	0,0000	1097
Max	13,53	0,48	9,16	19,92	0,02	64,19	0,52	12,69	0,08	0,49	0,02	0,34	0,75	0,00	2,51	0,02	10,66	0,0031	1151
Flux moyen (1h)	1,93	0,08	4,76	9,29	0,00	61,86	0,45	4,04	0,03	3,51	0,16	8,72	16,96	0,01	113,16	0,82	170,16	0,0562	1122
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.