

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	0.47	0.09	3.95	14.83	0.12	77.04	0.36	6.17	0.00	0.02	0.00	0.16	0.61	0.00	3.18	0.01	5.62	0.0000	1131
01:00	1.41	0.20	4.87	21.27	0.07	60.69	0.38	6.12	0.03	0.06	0.01	0.20	0.87	0.00	2.49	0.02	5.57	0.0012	1142
01:30	0.71	0.12	4.41	14.36	0.05	69.00	0.35	6.08	0.16	0.03	0.01	0.18	0.59	0.00	2.81	0.01	5.54	0.0067	1138
02:00	0.95	0.09	5.06	16.49	0.09	69.18	0.34	6.13	0.26	0.04	0.00	0.21	0.68	0.00	2.85	0.01	5.59	0.0107	1139
02:30	1.20	0.09	4.71	15.51	0.08	66.29	0.35	6.05	0.19	0.05	0.00	0.19	0.63	0.00	2.69	0.01	5.52	0.0078	1138
03:00	1.89	0.12	4.65	22.94	0.06	66.35	0.38	6.16	0.14	0.08	0.01	0.19	0.95	0.00	2.74	0.02	5.61	0.0060	1129
03:30	0.08	0.10	4.94	25.54	0.01	66.82	0.33	6.11	0.07	0.00	0.00	0.20	1.04	0.00	2.73	0.01	5.53	0.0029	1119
04:00	3.07	0.06	3.10	16.27	0.00	62.46	0.32	6.16	0.03	0.12	0.00	0.12	0.65	0.00	2.51	0.01	5.44	0.0012	1109
04:30	0.25	0.08	5.10	37.57	0.01	89.43	0.32	6.22	0.36	0.01	0.00	0.20	1.47	0.00	3.50	0.01	5.29	0.0139	1100
05:00	2.05	0.09	5.08	29.03	0.00	74.55	0.32	6.32	0.00	0.08	0.00	0.21	1.18	0.00	3.02	0.01	5.49	0.0000	1109
05:30	0.31	0.09	4.76	20.37	0.00	67.92	0.27	6.08	0.00	0.01	0.00	0.19	0.80	0.00	2.68	0.01	5.35	0.0000	1102
06:00	0.01	0.22	4.56	12.18	0.00	71.17	0.27	2.78	0.00	0.00	0.01	0.17	0.46	0.00	2.70	0.01	2.46	0.0000	1086
06:30	2.90	0.23	4.77	10.27	0.00	66.50	0.35	4.81	0.00	0.11	0.01	0.18	0.40	0.00	2.56	0.01	4.28	0.0000	1097
07:00	0.64	0.09	3.16	8.88	0.00	61.08	0.31	6.04	0.00	0.03	0.00	0.13	0.35	0.00	2.44	0.01	5.44	0.0000	1111
07:30	0.07	0.10	3.96	14.88	0.00	60.31	0.30	5.96	0.00	0.00	0.00	0.16	0.59	0.00	2.40	0.01	5.41	0.0000	1096
08:00	0.05	0.12	4.20	11.65	0.07	64.04	0.29	5.88	0.00	0.00	0.00	0.17	0.46	0.00	2.53	0.01	5.36	0.0000	1097
08:30	0.77	0.17	4.04	12.16	0.12	63.20	0.31	5.88	0.00	0.03	0.01	0.16	0.48	0.00	2.50	0.01	5.37	0.0000	1108
09:00	1.44	0.25	4.24	11.57	0.08	52.58	0.33	5.79	0.00	0.06	0.01	0.16	0.45	0.00	2.03	0.01	5.27	0.0000	1110
09:30	1.24	0.11	3.40	11.66	0.00	55.03	0.33	5.67	0.00	0.05	0.00	0.13	0.43	0.00	2.05	0.01	5.07	0.0000	1106
10:00	0.41	0.19	3.65	9.76	0.00	66.72	0.30	5.89	0.00	0.02	0.01	0.14	0.38	0.00	2.59	0.01	5.30	0.0000	1123
10:30	0.73	0.24	4.78	15.62	0.00	52.76	0.33	5.74	0.02	0.03	0.01	0.18	0.58	0.00	1.96	0.01	5.07	0.0008	1111
11:00	0.75	0.18	3.15	5.20	0.00	63.31	0.31	5.86	0.00	0.03	0.01	0.12	0.19	0.00	2.34	0.01	5.04	0.0000	1116
11:30	0.19	0.12	4.06	11.15	0.00	62.02	0.32	6.03	0.00	0.01	0.00	0.15	0.42	0.00	2.34	0.01	5.15	0.0000	1131
12:00	0.04	0.16	3.41	11.34	0.00	61.84	0.30	5.91	0.00	0.00	0.01	0.13	0.42	0.00	2.28	0.01	5.04	0.0000	1122
12:30	22.30	0.14	4.94	21.18	0.00	53.98	0.29	6.07	0.00	0.83	0.01	0.18	0.78	0.00	2.00	0.01	5.05	0.0000	1113
13:00	93.62	0.30	5.35	40.30	0.00	51.38	0.27	6.52	0.22	3.48	0.01	0.20	1.50	0.00	1.91	0.01	5.05	0.0083	1114
13:30	174.69	0.40	6.91	32.55	0.00	114.47	0.23	7.00	0.00	6.30	0.01	0.25	1.17	0.00	4.13	0.01	5.19	0.0001	1096
14:00	9.43	0.23	3.93	6.66	0.00	72.67	0.54	9.36	0.00	0.32	0.01	0.13	0.22	0.00	2.45	0.02	6.93	0.0000	1138
14:30	28.76	0.88	4.99	25.92	0.00	49.49	0.40	28.61	0.18	0.98	0.03	0.17	0.88	0.00	1.68	0.01	21.21	0.0062	1130
15:00	21.51	0.74	5.17	17.74	0.00	63.82	0.40	21.42	0.09	0.74	0.03	0.18	0.61	0.00	2.19	0.01	15.97	0.0032	1123
15:30	7.55	0.18	4.18	10.85	0.00	55.76	0.33	6.63	0.00	0.26	0.01	0.14	0.37	0.00	1.88	0.01	5.00	0.0000	1119
16:00	3.23	0.21	4.53	16.88	0.00	57.94	0.37	3.09	0.05	0.11	0.01	0.16	0.58	0.00	2.00	0.01	2.34	0.0016	1116
16:30	5.22	0.26	5.61	20.49	0.00	59.34	0.33	5.08	0.00	0.17	0.01	0.19	0.68	0.00	1.98	0.01	3.79	0.0000	1114
17:00	16.55	0.26	7.39	25.32	0.00	54.71	0.34	16.63	0.06	0.55	0.01	0.25	0.85	0.00	1.83	0.01	12.07	0.0021	1118
17:30	2.87	0.21	4.80	13.26	0.00	47.73	0.37	2.73	0.00	0.10	0.01	0.16	0.44	0.00	1.59	0.01	1.99	0.0000	1124
18:00	3.62	0.25	4.13	4.33	0.00	54.05	0.34	3.21	14.68	0.11	0.01	0.13	0.14	0.00	1.70	0.01	2.34	0.4612	1107
18:30	45.68	0.14	2.06	2.02	0.00	45.58	0.37	33.28	14.23	1.49	0.00	0.07	0.07	0.00	1.48	0.01	22.85	0.4627	1115
19:00	6.53	0.01	2.01	4.11	0.00	48.93	0.46	6.54	9.04	0.22	0.00	0.07	0.14	0.00	1.63	0.02	4.48	0.3012	1148
19:30	0.70	0.00	1.78	6.30	0.00	57.84	0.47	6.49	8.14	0.03	0.00	0.06	0.23	0.00	2.08	0.02	4.81	0.2926	1165
20:00	27.12	0.07	3.42	22.68	0.00	55.70	0.46	6.29	9.53	0.96	0.00	0.12	0.80	0.00	1.96	0.02	4.76	0.3357	1107
20:30	2.92	0.05	3.97	17.69	0.00	61.55	0.48	6.17	8.23	0.10	0.00	0.14	0.61	0.00	2.12	0.02	4.64	0.2829	1120
21:00	1.16	0.07	4.21	22.79	0.00	56.31	0.49	6.27	6.66	0.04	0.00	0.15	0.79	0.00	1.94	0.02	4.66	0.2297	1127
21:30	0.06	0.06	4.52	22.75	0.00	55.65	0.49	6.31	5.16	0.00	0.00	0.16	0.80	0.00	1.97	0.02	4.79	0.1824	1141
22:00	0.61	0.12	4.95	21.26	0.00	58.88	0.50	6.00	3.50	0.02	0.00	0.17	0.73	0.00	2.02	0.02	4.65	0.1202	1111
22:30	1.35	0.10	4.66	21.52	0.00	60.69	0.49	6.41	3.33	0.05	0.00	0.18	0.81	0.00	2.29	0.02	5.10	0.1257	1143
23:00	8.61	0.34	4.45	21.87	0.00	60.56	0.48	6.53	3.20	0.34	0.01	0.18	0.86	0.00	2.38	0.02	5.31	0.1258	1169
23:30	0.04	0.09	5.14	28.37	0.00	61.96	0.50	6.73	2.14	0.00	0.00	0.21	1.15	0.00	2.52	0.02	5.51	0.0870	1157
00:00	0.15	0.05	4.53	21.04	0.00	57.96	0.48	6.64	1.61	0.01	0.00	0.18	0.85	0.00	2.35	0.02	5.49	0.0655	1148
Min	0,01	0,00	1,78	2,02	0,00	45,58	0,23	2,73	0,00	0,00	0,00	0,06	0,07	0,00	1,48	0,01	1,99	0,0000	1086
Max	174,69	0,88	7,39	40,30	0,12	114,47	0,54	33,28	14,68	6,30	0,03	0,25	1,50	0,00	4,13	0,02	22,85	0,4627	1169
Flux moyen (kg/h)	7,05	0,18	4,37	17,26	0,02	62,23	0,37	6,48	1,90	18,05	0,31	7,83	31,14	0,03	111,99	0,66	288,79	3,1454	1122
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.