

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	0.10	0.08	4.50	11.44	0.00	61.10	0.46	6.10	0.01	0.00	0.00	0.18	0.46	0.00	2.45	0.02	5.45	0.0005	1111
01:00	0.30	0.06	3.89	10.42	0.00	61.54	0.47	6.10	0.00	0.01	0.00	0.15	0.42	0.00	2.45	0.02	5.43	0.0000	1120
01:30	5.50	0.06	4.35	15.19	0.00	60.39	0.44	6.18	0.00	0.22	0.00	0.18	0.62	0.00	2.45	0.02	5.51	0.0000	1112
02:00	3.22	0.02	4.05	14.19	0.00	63.11	0.43	6.18	0.00	0.13	0.00	0.17	0.58	0.00	2.59	0.02	5.56	0.0000	1117
02:30	0.73	0.02	4.21	14.05	0.00	59.86	0.48	6.04	0.00	0.03	0.00	0.17	0.56	0.00	2.40	0.02	5.44	0.0000	1116
03:00	0.59	0.02	4.96	15.71	0.00	63.40	0.46	6.11	0.00	0.02	0.00	0.20	0.63	0.00	2.56	0.02	5.44	0.0000	1118
03:30	1.11	0.05	4.57	14.69	0.00	59.68	0.46	6.18	0.00	0.05	0.00	0.19	0.60	0.00	2.43	0.02	5.52	0.0000	1127
04:00	0.58	0.05	4.22	11.16	0.00	62.23	0.43	6.08	0.04	0.02	0.00	0.17	0.45	0.00	2.49	0.02	5.42	0.0015	1119
04:30	1.24	0.09	4.71	14.64	0.00	59.75	0.44	6.09	0.00	0.05	0.00	0.19	0.59	0.00	2.41	0.02	5.44	0.0000	1113
05:00	2.29	0.08	4.70	14.15	0.00	60.12	0.44	6.08	0.00	0.09	0.00	0.19	0.56	0.00	2.40	0.02	5.39	0.0000	1117
05:30	4.70	0.14	4.23	9.13	0.00	63.11	0.44	6.21	0.00	0.19	0.01	0.17	0.37	0.00	2.57	0.02	5.49	0.0000	1128
06:00	14.21	0.26	4.04	10.10	0.00	63.15	0.48	3.41	0.00	0.57	0.01	0.16	0.40	0.00	2.53	0.02	3.06	0.0000	1134
06:30	0.95	0.24	4.80	10.25	0.00	62.68	0.49	3.61	0.00	0.04	0.01	0.19	0.41	0.00	2.49	0.02	3.26	0.0000	1135
07:00	0.60	0.08	3.89	7.49	0.00	62.63	0.51	6.00	0.00	0.02	0.00	0.16	0.30	0.00	2.53	0.02	5.47	0.0000	1120
07:30	1.57	0.50	5.40	18.77	0.00	61.37	0.57	3.98	0.00	0.06	0.02	0.22	0.76	0.00	2.50	0.02	3.63	0.0000	1124
08:00	1.31	0.65	5.92	11.52	0.00	61.66	0.52	1.22	0.00	0.05	0.03	0.23	0.45	0.00	2.41	0.02	1.11	0.0000	1109
08:30	0.86	0.45	4.09	7.87	0.00	60.24	0.67	0.81	0.00	0.03	0.02	0.16	0.31	0.00	2.38	0.03	0.74	0.0000	1116
09:00	2.03	0.55	4.58	7.52	0.00	63.89	0.64	1.92	0.00	0.08	0.02	0.18	0.30	0.00	2.52	0.03	1.75	0.0000	1116
09:30	1.97	0.50	5.36	12.75	0.00	59.10	0.59	1.86	0.00	0.08	0.02	0.21	0.51	0.00	2.35	0.02	1.70	0.0000	1120
10:00	1.12	0.41	5.81	13.27	0.00	56.37	0.59	1.05	0.00	0.04	0.02	0.23	0.52	0.00	2.23	0.02	0.95	0.0000	1105
10:30	6.87	0.39	4.71	8.92	0.00	67.23	0.61	6.49	0.00	0.27	0.02	0.19	0.35	0.00	2.66	0.02	5.88	0.0000	1104
11:00	1.27	0.34	4.78	11.38	0.00	60.15	0.67	1.21	0.00	0.05	0.01	0.19	0.45	0.00	2.39	0.03	1.09	0.0000	1125
11:30	1.74	0.38	5.57	14.24	0.00	61.83	0.70	1.62	0.00	0.07	0.02	0.22	0.56	0.00	2.45	0.03	1.47	0.0000	1123
12:00	22.16	1.35	5.02	16.15	0.00	60.95	0.57	21.27	0.00	0.89	0.05	0.20	0.65	0.00	2.44	0.02	19.37	0.0000	1134
12:30	1.85	0.39	6.01	45.63	0.00	67.65	0.64	1.73	0.00	0.07	0.02	0.24	1.78	0.00	2.65	0.02	1.58	0.0000	1124
13:00	1.62	0.32	4.79	71.59	0.01	69.91	0.59	1.54	0.09	0.06	0.01	0.19	2.84	0.00	2.77	0.02	1.40	0.0034	1127
13:30	2.13	0.32	3.14	22.56	0.00	52.04	0.77	1.99	0.00	0.08	0.01	0.12	0.88	0.00	2.04	0.03	1.82	0.0000	1120
14:00	1.31	0.27	2.77	23.40	0.01	60.93	0.74	1.21	0.00	0.05	0.01	0.11	0.91	0.00	2.38	0.03	1.11	0.0000	1128
14:30	0.87	0.26	5.38	40.72	0.00	63.36	0.79	0.79	0.00	0.03	0.01	0.21	1.61	0.00	2.51	0.03	0.72	0.0000	1121
15:00	0.57	0.02	2.68	10.06	0.00	59.63	0.71	5.87	0.00	0.02	0.00	0.11	0.41	0.00	2.44	0.03	5.34	0.0000	1127
15:30	0.81	0.02	2.02	12.57	0.00	64.16	0.70	6.13	0.00	0.03	0.00	0.08	0.52	0.00	2.64	0.03	5.59	0.0000	1135
16:00	0.63	0.02	4.57	33.16	0.00	61.03	0.78	6.05	0.00	0.03	0.00	0.19	1.36	0.00	2.50	0.03	5.52	0.0000	1135
16:30	1.22	0.03	5.24	29.77	0.00	56.81	0.75	6.01	0.00	0.05	0.00	0.21	1.22	0.00	2.33	0.03	5.46	0.0000	1116
17:00	1.17	0.05	4.41	20.09	0.00	60.48	0.75	5.98	0.00	0.05	0.00	0.17	0.79	0.00	2.37	0.03	5.28	0.0000	1120
17:30	0.48	0.03	4.10	17.65	0.00	62.00	0.72	6.08	0.00	0.02	0.00	0.16	0.68	0.00	2.39	0.03	5.20	0.0000	1137
18:00	0.38	0.13	4.72	19.88	0.00	62.94	0.89	2.91	0.00	0.01	0.01	0.18	0.77	0.00	2.43	0.03	2.52	0.0000	1144
18:30	0.37	0.12	4.32	11.04	0.00	62.97	0.73	3.39	0.00	0.01	0.00	0.16	0.42	0.00	2.40	0.03	2.93	0.0000	1143
19:00	0.26	0.04	4.62	17.77	0.00	60.54	0.73	6.07	0.00	0.01	0.00	0.18	0.69	0.00	2.36	0.03	5.29	0.0000	1140
19:30	1.19	0.03	3.55	11.21	0.00	62.48	0.82	6.14	0.00	0.05	0.00	0.14	0.45	0.00	2.50	0.03	5.48	0.0000	1163
20:00	0.40	0.03	4.72	15.99	0.00	60.71	0.87	6.09	0.00	0.02	0.00	0.19	0.65	0.00	2.47	0.04	5.52	0.0000	1142
20:30	0.64	0.05	4.13	11.76	0.00	61.47	0.88	5.95	0.06	0.03	0.00	0.16	0.47	0.00	2.46	0.04	5.42	0.0026	1124
21:00	0.39	0.05	4.77	13.78	0.00	61.49	0.91	6.01	0.16	0.02	0.00	0.19	0.56	0.00	2.51	0.04	5.48	0.0066	1124
21:30	1.06	0.11	4.34	13.99	0.00	65.94	0.88	6.10	0.34	0.04	0.00	0.18	0.57	0.00	2.71	0.04	5.57	0.0142	1127
22:00	0.48	0.14	4.37	13.75	0.00	63.68	0.77	6.01	0.49	0.02	0.01	0.18	0.56	0.00	2.57	0.03	5.48	0.0199	1132
22:30	6.15	0.28	5.26	21.08	0.00	56.07	0.57	7.15	0.59	0.25	0.01	0.21	0.85	0.00	2.26	0.02	6.51	0.0236	1130
23:00	2.12	0.30	4.63	12.06	0.00	60.23	0.47	1.99	0.57	0.08	0.01	0.18	0.47	0.00	2.37	0.02	1.82	0.0223	1111
23:30	2.55	0.30	4.81	13.58	0.00	65.87	0.45	2.40	0.42	0.10	0.01	0.19	0.54	0.00	2.60	0.02	2.19	0.0167	1119
00:00	1.78	0.25	5.04	13.94	0.00	59.82	0.56	1.67	0.32	0.07	0.01	0.20	0.55	0.00	2.35	0.02	1.53	0.0126	1125
Min	0.10	0.02	2.02	7.49	0.00	52.04	0.43	0.79	0.00	0.00	0.00	0.08	0.30	0.00	2.04	0.02	0.72	0.0000	1104
Max	22.16	1.35	6.01	71.59	0.01	69.91	0.91	21.27	0.59	0.89	0.05	0.24	2.84	0.00	2.77	0.04	19.37	0.0236	1163
Flux moyen (kg/h)	2.24	0.21	4.52	16.92	0.00	61.62	0.63	4.73	0.06	4.30	0.41	8.65	32.38	0.00	118.06	1.20	204.33	0.1238	1125
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.