

Paramètre	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hq	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hq	T2S
Foyer																			
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	mg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	6.56	0.18	5.44	1.77	0.19	56.88	0.20	0.00	0.03	0.31	0.01	0.25	0.08	0.01	2.67	0.01	0.00	0.0013	1140
01:00	4.25	0.19	7.42	12.68	0.22	55.29	0.22	0.00	0.04	0.20	0.01	0.35	0.61	0.01	2.64	0.01	0.00	0.0017	1124
01:30	3.38	0.19	8.79	6.47	0.22	61.45	0.18	0.00	0.23	0.16	0.01	0.41	0.30	0.01	2.84	0.01	0.00	0.105	1121
02:00	3.40	0.20	5.12	4.95	0.23	59.41	0.17	0.00	0.25	0.16	0.01	0.23	0.23	0.01	2.71	0.01	0.00	0.0112	1133
02:30	4.05	0.16	7.33	7.65	0.17	55.43	0.19	0.00	0.42	0.19	0.01	0.34	0.35	0.01	2.56	0.01	0.00	0.0194	1131
03:00	6.61	0.14	6.24	3.44	0.13	60.99	0.21	0.00	0.04	0.31	0.01	0.29	0.16	0.01	2.85	0.01	0.00	0.0018	1142
03:30	4.31	0.16	4.28	2.55	0.14	54.86	0.19	0.00	0.02	0.20	0.01	0.20	0.12	0.01	2.54	0.01	0.00	0.0008	1135
04:00	4.85	0.16	3.97	3.22	0.17	61.55	0.21	0.00	0.03	0.22	0.01	0.18	0.14	0.01	2.75	0.01	0.00	0.0012	1126
04:30	4.34	0.21	5.58	8.69	0.23	56.42	0.18	0.00	0.04	0.20	0.01	0.26	0.40	0.01	2.58	0.01	0.00	0.0019	1127
05:00	5.34	0.22	7.11	6.60	0.37	64.64	0.28	0.00	0.08	0.24	0.01	0.31	0.29	0.02	2.84	0.01	0.00	0.0037	1136
05:30	4.60	0.18	5.15	4.39	0.44	62.60	0.30	0.00	0.13	0.20	0.01	0.22	0.19	0.02	2.72	0.01	0.00	0.0056	1133
06:00	6.27	0.19	4.55	3.63	0.48	70.72	0.33	0.00	0.12	0.27	0.01	0.20	0.16	0.02	3.04	0.01	0.00	0.0052	1138
06:30	5.06	0.19	5.51	12.52	0.48	62.63	0.29	0.00	0.27	0.22	0.01	0.24	0.55	0.02	2.75	0.01	0.00	0.0118	1142
07:00	11.12	0.23	6.96	10.08	0.30	53.36	0.27	0.00	0.04	0.52	0.01	0.33	0.47	0.01	2.49	0.01	0.00	0.0017	1136
07:30	4.34	0.23	5.41	6.29	0.26	59.23	0.29	0.00	0.13	0.20	0.01	0.25	0.29	0.01	2.74	0.01	0.00	0.0062	1137
08:00	3.90	0.20	7.30	13.96	0.24	57.81	0.27	0.00	0.42	0.18	0.01	0.34	0.64	0.01	2.66	0.01	0.00	0.0195	1136
08:30	4.50	0.18	6.99	9.04	0.21	61.12	0.30	0.00	0.29	0.20	0.01	0.32	0.41	0.01	2.76	0.01	0.00	0.0131	1130

[illegible]**Commentaires :**

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.