

UVE	Mesures corrigées à 11% d'O ₂ - IC 95%						Flux massique en kg							Process
Ligne	HCl	SO ₂	NO _x	COT	NH ₃	Poussières	Q-HCl	Q-CO	Q-SO ₂	Q-NO _x	Q-COT	Q-NH ₃	Q-Pouss	T2S
Unité	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	kg	kg	kg	kg	kg	kg	kg	°C
VLE Jour	9	40	80	9	30	5	17.0	86.0	77.0	154.0	17.0	48.0	10.0	
VLE 30 min	60	200	400	20	30	30								
Autre seuil						150								850.00
Moy.	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h
00:30	7.72	27.91	54.02	2.14	0.56	1.01	0.31	0.69	1.14	2.20	0.09	0.02	0.04	1186
01:00	7.00	21.17	61.40	0.93	0.58	1.05	0.29	0.06	0.89	2.58	0.04	0.02	0.04	1153
01:30	8.21	26.88	59.07	0.17	0.59	1.07	0.35	1.14	1.14	2.49	0.01	0.02	0.05	1136
02:00	7.78	18.19	59.15	0.19	0.56	1.07	0.32	0.05	0.75	2.44	0.01	0.02	0.04	1152
02:30	6.99	15.08	55.62	2.22	0.55	1.09	0.29	0.70	0.63	2.31	0.09	0.02	0.05	1143
03:00	8.03	11.84	58.12	0.11	0.58	1.13	0.32	0.13	0.48	2.34	0.00	0.02	0.05	1137
03:30	7.13	1.42	67.58	0.11	0.42	1.16	0.30	0.06	0.06	2.80	0.00	0.02	0.05	1168
04:00	6.93	5.18	64.68	0.08	0.47	1.12	0.30	0.07	0.22	2.81	0.00	0.02	0.05	1157
04:30	8.36	7.55	66.63	0.11	0.52	1.14	0.36	0.08	0.32	2.87	0.00	0.02	0.05	1145
05:00	7.71	5.82	64.28	0.09	0.50	1.05	0.34	0.07	0.25	2.80	0.00	0.02	0.0	