

UVE	Mesures corrigées à 11% d'O ₂ - IC 95%						Flux massique en kg							Process
Ligne 1	HCl	SO ₂	NO _x	COT	NH ₃	Poussières	Q-HCL	Q-CO	Q-SO ₂	Q-NO _x	Q-COT	Q-NH ₃	Q-Pouss	T2S
Unité	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	kg	kg	kg	kg	kg	kg	kg	°C
VLE Jour	9	40	80	9	30	5	17.0	86.0	77.0	154.0	17.0	48.0	10.0	
VLE 30 min	60	200	400	20	30	30								
Autre seuil						150								850.00
Moy.	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h
00:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
01:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
01:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
02:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
02:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
03:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
03:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
04:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
04:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
05:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
05:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
06:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
06:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
07:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
07:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
08:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
08:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
09:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
09:30	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
10:00	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off	Off
10:30	2.08	0.00	8.94	0.20	0.61	0.94	0.06	0.03	0.00	0.27	0.01	0.02	0.03	994
11:00	2.57	0.00	30.56	0.18	0.75	0.78	0.08	0.05	0.00	0.94	0.01	0.02	0.02	1190
11:30	2.40	1.97	38.42	0.17	0.67	1.21	0.08	0.19	0.07	1.30	0.01	0.02	0.04	1131
12:00	2.87	1.43	53.82	0.24	0.71	0.70	0.10	0.06	0.05	1.88	0.01	0.02	0.02	1158
12:30	3.02	2.58	52.90	0.24	0.69	0.67	0.11	0.14	0.09	1.87	0.01	0.02	0.02	1112
13:00	3.47	6.55	58.34	0.24	0.70	0.65	0.13	0.09	0.25	2.20	0.01	0.03	0.02	1152
13:30	4.91	8.32	62.08	0.26	0.72	0.68	0.19	0.12	0.32	2.41	0.01	0.03	0.03	1141
14:00	4.66	3.16	62.42	0.25	0.76	0.58	0.19	0.09	0.13	2.51	0.01	0.03	0.02	1154
14:30	4.53	2.49	57.17	0.26	0.69	0.66	0.18	0.11	0.10	2.21	0.01	0.03	0.03	1097
15:00	4.71	3.55	61.26	0.19	0.62	0.56	0.18	0.08	0.13	2.32	0.01	0.02	0.02	1142
15:30	4.62	1.54	66.92	0.23	0.70	0.50	0.18	0.08	0.06	2.63	0.01	0.03	0.02	1190
16:00	6.57	12.19	60.12	0.20	0.64	0.46	0.27	0.09	0.50	2.47	0.01	0.03	0.02	1158
16:30	8.09	13.69	61.84	0.18	0.61	0.43	0.35	0.12	0.59	2.65	0.01	0.03	0.02	1114
17:00	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint
17:30	5.93	5.32	41.36	0.15	0.78	0.35	0.26	0.11	0.23	1.80	0.01	0.03	0.02	1152
18:00	6.48	9.69	57.38	0.15	0.78	0.36	0.29	0.08	0.43	2.54	0.01	0.03	0.02	1154
18:30	7.29	7.39	63.84	0.15	0.72	0.37	0.31	0.08	0.32	2.73	0.01	0.03	0.02	1152
19:00	8.41	9.90	62.25	0.15	0.72	0.35	0.37	0.08	0.44	2.74	0.01	0.03	0.02	1143
19:30	9.18	10.40	71.86	0.15	0.73	0.36	0.40	0.09	0.46	3.15	0.01	0.03	0.02	1133
20:00	10.08	14.03	63.14	0.15	0.70	0.36	0.44	0.08	0.61	2.75	0.01	0.03	0.02	1138
20:30	8.46	7.02	65.24	0.15	0.70	0.34	0.37	0.07	0.31	2.84	0.01	0.03	0.01	1123
21:00	9.52	8.52	62.35	0.15	0.63	0.34	0.41	0.07	0.36	2.66	0.01	0.03	0.01	1120
21:30	9.10	8.05	64.49	0.15	0.67	0.34	0.40	0.06	0.35	2.83	0.01	0.03	0.01	1154
22:00	8.65	5.82	69.16	0.15	0.63	0.35	0.37	0.09	0.25	2.99	0.01	0.03	0.02	1118
22:30	9.25	7.24	66.66	0.14	0.66	0.36	0.40	0.08	0.31	2.87	0.01	0.03	0.02	1128
23:00	9.18	8.42	65.22	0.13	0.62	0.37	0.41	0.07	0.37	2.90	0.01	0.03	0.02	1133
23:30	9.71	8.27	60.56	0.09	0.61	0.41	0.41	0.06	0.35	2.57	0.00	0.03	0.02	1120
00:00	10.53	10.60	61.29	0.15	0.58	0.41	0.45	0.06	0.45	2.61	0.01	0.02	0.02	1127
min	1,26	0,00	0,78	0,07	0,51	0,34	0,00	0,00	0,00	0,00	0,00	0,00	0,00	994
max	10,53	14,03	71,86	0,26	0,78	1,46	0,45	0,19	0,61	3,15	0,01	0,03	0,04	1190
moyenne	6,53	6,60	57,39	0,18	0,68	0,52								1132
Total							7,65	9,04	7,80	65,98	0,20	0,77	0,57	

Synthèse des dépassements & indisponibilités	seuil	HCl	SO ₂	CO	NO _x	NH ₃	COT	Poussières
Compteur dépassement VLE 30 min	60H/An	00:00	00:00	00:00	00:00	00:00	00:00	00:00
Nombre de dépassement moyenne jour	/	0	0	0	0	0	0	0
% de moyennes 10min <150 mg/Nm ³	/			100,00	8,83			
Nombre de dépassement VLE Flux Jour	/	0	0	0	0	0	0	0
Nombre de moyenne jour invalide	10j/An	0	0	0	0	0	0	0
Compteur indisponibilité AMS	60H/An				00:40			
Compteur indisponibilité Opacimètre	60H/An							00:00
Compteur indisponibilité 10h consécutive (Indispo)	10H				0			0
Disponibilité AMESA %	>85% en cumul annuel				99,65			

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.

10h00 : redémarrage suite à une intervention pour une fuite d'eau dans la chaudière