

UVE	Mesures corrigées à 11% d O2 - IC 95%						Flux massique en kg								Process
Lasse	HCl	SO2	NOx	COT	NH3	Poussières	Q-HCL	Q-CO	Q-SO2	Q-NOX	Q-COT	Q-NH3	Q-Pouss	T2S	
Ligne 1															
Unité	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	kg	kg	kg	kg	kg	kg	kg	°C	
VLE Jour	9	40	80	9	30	5	17.0	86.0	77.0	154.0	17.0	48.0	10.0		
VLE 30 min	60	200	400	20	30	30									
Autre seuil						150								850.00	
Moy.	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	
00:30	3.03	42.24	57.25	0.82	0.27	1.33	0.14	0.10	1.89	2.56	0.04	0.01	0.06	1141	
01:00	2.74	9.34	58.54	0.82	0.29	1.33	0.12	0.09	0.42	2.63	0.04	0.01	0.06	1164	
01:30	2.75	30.44	57.25	0.84	0.27	1.37	0.12	0.08	1.37	2.58	0.04	0.01	0.06	1137	
02:00	3.25	30.07	60.24	0.85	0.27	1.39	0.15	0.11	1.37	2.75	0.04	0.01	0.06	1150	
02:30	3.51	40.69	57.45	0.84	0.30	1.35	0.16	0.08	1.90	2.69	0.04	0.01	0.06	1128	
03:00	3.67	33.88	55.73	0.83	0.28	1.35	0.17	0.08	1.54	2.53	0.04	0.01	0.06	1120	
03:30	3.69	20.06	59.42	0.81	0.29	1.33	0.17	0.06	0.91	2.71	0.04	0.01	0.06	1162	
04:00	4.23	20.51	54.95	0.81	0.28	1.33	0.19	0.06	0.92	2.46	0.04	0.01	0.06	1135	
04:30	6.67	26.80	57.84	0.81	0.27	1.31	0.29	0.04	1.17	2.52	0.04	0.01	0.06	1171	
05:00	8.89	20.16	57.81	0.66	0.29	1.26	0.38	0.05	0.86	2.46	0.03	0.01	0.05	1152	
05:30	7.40	18.07	66.87	0.59	0.26	1.07	0.29	0.04	0.72	2.66	0.02	0.01	0.04	1182	
06:00	7.17	14.69	66.79	0.23	0.28	1.06	0.30	0.04	0.62	2.81	0.01	0.01	0.04	1162	
06:30	7.09	12.04	71.66	0.55	0.26	1.15	0.30	0.06	0.51	3.06	0.02	0.01	0.05	1161	
07:00	9.22	17.33	57.79	0.66	0.21	1.25	0.41	0.06	0.77	2.56	0.03	0.01	0.06	1124	
07:30	6.75	6.07	59.53	0.84	0.21	1.36	0.30	0.07	0.27	2.66	0.04	0.01	0.06	1132	
08:00	5.80	10.46	57.24	0.88	0.27	1.42	0.26	0.09	0.47	2.60	0.04	0.01	0.06	1121	
08:30	8.27	21.68	57.62	0.88	0.25	1.42	0.38	0.07	1.00	2.67	0.04	0.01	0.07	1144	
09:00	9.35	26.42	60.07	0.87	0.25	1.43	0.42	0.11	1.20	2.72	0.04	0.01	0.06	1125	
09:30	5.66	11.92	56.56	0.81	0.23	1.32	0.26	0.09	0.55	2.62	0.04	0.01	0.06	1137	
10:00	6.79	5.99	54.31	0.85	0.22	1.36	0.29	0.09	0.26	2.32	0.04	0.01	0.06	1112	
10:30	5.60	3.36	44.01	0.89	0.24	1.39	0.21	0.13	0.13	1.64	0.03	0.01	0.05	1022	
11:00	10.55	17.19	54.83	0.61	0.19	0.91	0.43	0.06	0.69	2.21	0.02	0.01	0.04	1084	
11:30	10.01	11.32	52.43	0.42	0.20	0.59	0.36	0.07	0.41	1.90	0.02	0.01	0.02	1120	
12:00	7.14	4.85	56.80	0.37	0.21	0.52	0.28	0.04	0.19	2.25	0.01	0.01	0.02	1147	
12:30	5.59	6.33	57.83	0.37	0.27	0.53	0.22	0.05	0.25	2.27	0.01	0.01	0.02	1163	
13:00	6.42	4.12	58.95	0.38	0.23	0.54	0.26	0.05	0.16	2.36	0.02	0.01	0.02	1142	
13:30	6.94	9.50	59.81	0.36	0.24	0.50	0.29	0.05	0.40	2.49	0.02	0.01	0.02	1143	
14:00	9.42	11.16	55.39	0.37	0.25	0.51	0.39	0.06	0.46	2.31	0.02	0.01	0.02	1123	
14:30	9.99	28.05	59.64	0.37	0.23	0.53	0.43	0.07	1.20	2.55	0.02	0.01	0.02	1096	
15:00	5.74	15.40	57.01	0.38	0.22	0.54	0.25	0.06	0.68	2.51	0.02	0.01	0.02	1098	
15:30	9.76	25.18	58.85	0.38	0.20	0.55	0.42	0.07	1.09	2.55	0.02	0.01	0.02	1096	
16:00	8.50	29.96	55.33	0.37	0.26	0.52	0.37	0.06	1.31	2.42	0.02	0.01	0.02	1105	
16:30	7.13	20.45	59.63	0.38	0.24	0.54	0.32	0.06	0.91	2.64	0.02	0.01	0.02	1123	
17:00	5.24	27.43	60.93	0.44	0.23	0.76	0.23	1.03	1.22	2.72	0.02	0.01	0.03	1129	
17:30	4.98	46.99	64.53	0.54	0.15	1.39	0.21	0.07	1.98	2.72	0.02	0.01	0.06	1129	
18:00	5.19	64.17	66.32	0.25	0.23	1.30	0.22	0.05	2.72	2.81	0.01	0.01	0.06	1129	
18:30	5.63	42.39	65.50	0.67	0.19	1.07	0.24	0.07	1.79	2.77	0.03	0.01	0.05	1133	
19:00	5.54	43.30	54.82	0.57	0.22	0.90	0.25	0.06	1.92	2.43	0.03	0.01	0.04	1121	
19:30	5.07	23.02	59.03	0.64	0.25	1.01	0.22	0.09	1.01	2.58	0.03	0.01	0.04	1151	
20:00	6.96	28.32	57.55	0.67	0.23	1.05	0.31	0.06	1.24	2.53	0.03	0.01	0.05	1121	
20:30	10.79	31.79	59.31	0.63	0.24	1.01	0.48	0.06	1.42	2.64	0.03	0.01	0.05	1128	
21:00	9.18	29.33	57.08	0.65	0.23	1.03	0.41	0.06	1.30	2.53	0.03	0.01	0.05	1126	
21:30	10.07	22.21	58.99	0.67	0.26	1.05	0.45	0.07	0.98	2.61	0.03	0.01	0.05	1137	
22:00	5.68	8.38	54.83	0.67	0.25	1.06	0.25	0.08	0.37	2.42	0.03	0.01	0.05	1111	
22:30	8.69	32.69	56.10	0.63	0.21	0.99	0.39	0.53	1.48	2.55	0.03	0.01	0.04	1118	
23:00	8.68	31.03	57.68	0.60	0.21	0.93	0.36	0.03	1.30	2.42	0.03	0.01	0.04	1134	
23:30	5.34	27.65	57.33	0.59	0.23	0.90	0.22	0.03	1.13	2.35	0.02	0.01	0.04	1139	
00:00	6.76	36.09	56.50	0.60	0.23	0.93	0.29	0.10	1.53	2.39	0.03	0.01	0.04	1136	
min	2,74	3,36	44,01	0,23	0,15	0,50	0,12	0,03	0,13	1,64	0,01	0,01	0,02	1022	
max	10,79	64,17	71,66	0,89	0,30	1,43	0,48	1,03	2,72	3,06	0,04	0,01	0,07	1182	
moyenne	6,72	22,93	58,37	0,62	0,24	1,04								1132	
Total							13,87	13,19	48,01	121,14	1,29	0,50	2,17		

Synthèse des dépassements & indisponibilités	seuil	HCl	SO2	CO	NOx	NH3	COT	Poussieres
Compteur dépassement VLE 30 min	60H/An	00:00	00:00	00:00	00:00	00:00	00:00	00:00
Nombre de dépassement moyenne jour	/	0	0	0	0	0	0	0
% de moyennes 10min <150 mg/Nm3 & moyenne jour CO	/			100,00	6,28			
Nombre de dépassement VLE Flux Jour	/	0	0	0	0	0	0	0