

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	5.79	0.26	2.98	7.59	0.04	58.98	0.40	6.04	0.04	0.26	0.01	0.14	0.35	0.00	2.70	0.02	5.78	0.0016	1111
01:00	4.45	0.28	4.17	10.67	0.04	63.40	0.41	4.56	0.03	0.20	0.01	0.19	0.48	0.00	2.84	0.02	4.34	0.0013	1078
01:30	5.12	0.29	4.04	8.88	0.02	61.41	0.38	5.30	0.04	0.23	0.01	0.18	0.39	0.00	2.73	0.02	4.96	0.0016	1076
02:00	3.12	0.28	4.69	12.44	0.02	60.94	0.40	3.23	0.04	0.14	0.01	0.20	0.54	0.00	2.65	0.02	2.96	0.0016	1085
02:30	3.27	0.27	4.89	12.35	0.02	63.55	0.35	3.40	0.04	0.14	0.01	0.21	0.54	0.00	2.77	0.02	3.11	0.0016	1093
03:00	5.08	0.30	5.08	11.99	0.02	62.10	0.38	5.29	0.03	0.22	0.01	0.22	0.53	0.00	2.75	0.02	4.90	0.0013	1094
03:30	3.49	0.27	5.07	13.48	0.02	61.33	0.35	3.65	0.04	0.16	0.01	0.23	0.60	0.00	2.74	0.02	3.40	0.0017	1100
04:00	3.34	0.28	5.19	12.77	0.03	61.68	0.40	3.48	0.04	0.15	0.01	0.23	0.57	0.00	2.76	0.02	3.26	0.0017	1093
04:30	4.19	0.29	4.85	8.68	0.03	62.31	0.43	4.35	0.04	0.19	0.01	0.22	0.39	0.00	2.80	0.02	4.11	0.0017	1101
05:00	3.56	0.28	5.69	13.71	0.03	61.35	0.41	3.69	0.03	0.16	0.01	0.26	0.62	0.00	2.76	0.02	3.50	0.0014	1093
05:30	3.50	0.28	5.73	15.07	0.02	61.86	0.34	3.61	0.32	0.16	0.01	0.25	0.67	0.00	2.75	0.02	3.39	0.0141	1093
06:00	4.91	0.29	4.06	9.64	0.04	61.76	0.45	4.99	0.19	0.22	0.01	0.18	0.43	0.00	2.77	0.02	4.79	0.0086	1097
06:30	3.97	0.27	5.20	14.79	0.02	62.45	0.35	4.45	0.16	0.18	0.01	0.24	0.67	0.00	2.85	0.02	4.24	0.0073	1096
07:00	2.38	0.30	6.03	6.40	0.03	56.39	0.20	7.20	0.05	0.11	0.01	0.28	0.29	0.00	2.59	0.01	6.91	0.0021	1107
07:30	2.89	0.31	5.69	12.30	0.03	49.23	0.22	7.22	0.04	0.13	0.01	0.26	0.57	0.00	2.29	0.01	6.98	0.0017	1106
08:00	2.29	0.30	5.52	8.65	0.03	56.32	0.18	7.17	0.04	0.10	0.01	0.25	0.39	0.00	2.57	0.01	6.84	0.0017	1093
08:30	2.77	0.29	4.76	4.94	0.04	50.96	0.23	7.21	0.04	0.13	0.01	0.22	0.23	0.00	2.37	0.01	7.00	0.0016	1105
09:00	4.42	0.32	4.79	3.20	0.02	56.17	0.20	7.02	0.03	0.20	0.01	0.22	0.15	0.00	2.55	0.01	6.81	0.0014	1117
09:30	3.80	0.29	5.11	8.34	0.04	52.59	0.21	7.14	0.04	0.18	0.01	0.24	0.39	0.00	2.45	0.01	7.00	0.0017	1112
10:00	4.44	0.30	5.26	4.04	0.11	55.20	0.17	6.98	0.04	0.20	0.01	0.24	0.18	0.00	2.51	0.01	6.85	0.0018	1101
10:30	4.63	0.31	4.44	7.92	0.17	53.56	0.21	7.14	0.04	0.21	0.01	0.21	0.37	0.01	2.48	0.01	7.01	0.0017	1103
11:00	3.64	0.29	5.30	8.78	0.11	50.88	0.20	7.10	0.03	0.17	0.01	0.24	0.40	0.01	2.34	0.01	6.93	0.0014	1104
11:30	3.48	0.30	5.21	5.60	0.06	55.41	0.21	7.08	0.04	0.16	0.01	0.24	0.26	0.00	2.55	0.01	6.93	0.0017	1106
12:00	4.84	0.32	4.69	5.78	0.06	53.38	0.21	7.17	0.04	0.22	0.01	0.22	0.27	0.00	2.47	0.01	7.04	0.0018	1111
12:30	4.32	0.30	5.87	9.71	0.06	51.71	0.23	7.18	0.04	0.20	0.01	0.27	0.45	0.00	2.41	0.01	7.04	0.0017	1096
13:00	2.11	0.30	5.88	7.71	0.02	50.90	0.20	7.17	0.03	0.10	0.01	0.27	0.35	0.00	2.33	0.01	6.87	0.0014	1113
13:30	4.01	0.31	5.69	3.62	0.02	56.71	0.21	7.17	0.04	0.18	0.01	0.26	0.16	0.00	2.58	0.01	6.88	0.0017	1109
14:00	3.16	0.29	4.51	2.42	0.05	51.62	0.20	7.13	0.04	0.15	0.01	0.21	0.11	0.00	2.39	0.01	6.99	0.0017	1106
14:30	3.22	0.29	5.25	8.32	0.02	52.05	0.19	7.18	0.04	0.15	0.01	0.24	0.38	0.00	2.37	0.01	6.92	0.0016	1096
15:00	4.76	0.31	5.55	7.44	0.02	55.78	0.19	7.29	0.03	0.22	0.01	0.25	0.34	0.00	2.56	0.01	7.04	0.0013	1115
15:30	4.83	0.28	4.35	6.44	0.02	55.49	0.32	7.25	0.04	0.22	0.01	0.20	0.30	0.00	2.57	0.01	7.05	0.0016	1144
16:00	26.19	1.81	4.39	11.28	0.05	58.33	0.44	25.21	0.04	1.13	0.08	0.19	0.49	0.00	2.52	0.02	24.71	0.0019	1118
16:30	7.10	0.31	3.66	6.87	0.03	62.73	0.34	7.23	0.04	0.32	0.01	0.17	0.31	0.00	2.84	0.02	7.00	0.0016	1117
17:00	4.58	0.27	3.71	8.49	0.02	61.96	0.41	4.72	0.03	0.20	0.01	0.16	0.38	0.00	2.76	0.02	4.45	0.0013	1123
17:30	7.43	0.28	3.58	4.49	0.01	62.34	0.42	7.29	0.04	0.32	0.01	0.15	0.19	0.00	2.66	0.02	6.92	0.0016	1127
18:00	6.63	0.30	2.97	3.50	0.02	62.12	0.35	6.51	0.04	0.29	0.01	0.13	0.15	0.00	2.69	0.02	6.27	0.0017	1131
18:30	7.53	0.26	3.04	4.55	0.09	63.99	0.39	7.69	0.04	0.34	0.01	0.14	0.21	0.00	2.89	0.02	7.54	0.0016	1127
19:00	4.54	0.30	4.08	2.97	0.07	52.60	0.19	6.96	0.03	0.21	0.01	0.19	0.14	0.00	2.41	0.01	6.83	0.0014	1120
19:30	4.11	0.33	4.56	3.84	0.04	53.35	0.17	6.80	0.04	0.19	0.01	0.21	0.17	0.00	2.41	0.01	6.66	0.0017	1084
20:00	3.28	0.30	4.01	1.61	0.05	54.18	0.16	6.78	0.04	0.15	0.01	0.18	0.07	0.00	2.42	0.01	6.64	0.0017	1101
20:30	3.69	0.29	3.56	2.67	0.05	51.54	0.16	6.91	0.04	0.17	0.01	0.16	0.12	0.00	2.34	0.01	6.77	0.0016	1118
21:00	3.98	0.31	3.79	2.13	0.04	53.75	0.20	7.02	0.03	0.18	0.01	0.17	0.10	0.00	2.47	0.01	6.88	0.0013	1121
21:30	5.07	0.33	3.38	0.84	0.05	52.40	0.20	6.79	0.04	0.23	0.01	0.15	0.04	0.00	2.35	0.01	6.66	0.0017	1108
22:00	11.19	0.49	3.02	1.98	0.05	52.52	0.18	6.62	0.04	0.49	0.02	0.13	0.09	0.00	2.30	0.01	6.46	0.0017	1081
22:30	2.56	0.30	3.51	3.89	0.03	49.77	0.15	6.93	0.04	0.11	0.01	0.16	0.17	0.00	2.24	0.01	6.62	0.0016	1083
23:00	2.52	0.31	3.45	1.99	0.02	54.17	0.14	6.99	0.03	0.11	0.01	0.15	0.09	0.00	2.37	0.01	6.47	0.0013	1094
23:30	1.19	0.29	4.10	4.71	0.00	55.63	0.17	7.16	0.04	0.05	0.01	0.18	0.20	0.00	2.41	0.01	6.42	0.0016	1104
00:00	1.40	0.29	5.02	6.58	0.01	54.97	0.14	7.17	0.04	0.06	0.01	0.22	0.29	0.00	2.40	0.01	6.51	0.0016	1111
Min	1,19	0,26	2,97	0,84	0,00	49,23	0,14	3,23	0,03	0,05	0,01	0,13	0,04	0,00	2,24	0,01	2,96	0,0013	1076
Max	26,19	1,81	6,03	15,07	0,17	63,99	0,45	25,21	0,32	1,13	0,08	0,28	0,67	0,01	2,89	0,02	24,71	0,0141	1144
Flux moyen (kg/h)	4,64	0,33	4,57	7,21	0,04	56,75	0,27	6,26	0,05	9,99	0,71	9,91	15,60	0,09	122,74	0,58	307,64	0,1019	1105
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.