

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	2.50	0.29	4.51	10.17	0.03	53.19	0.32	6.94	0.04	0.12	0.01	0.21	0.47	0.00	2.46	0.01	6.81	0.0017	1101
01:00	3.44	0.31	5.20	12.37	0.02	50.31	0.33	6.99	0.03	0.16	0.01	0.24	0.57	0.00	2.33	0.02	6.80	0.0015	1090
01:30	1.93	0.29	6.21	10.42	0.03	54.03	0.34	7.17	0.03	0.09	0.01	0.29	0.48	0.00	2.49	0.02	6.81	0.0016	1102
02:00	2.13	0.29	5.02	5.59	0.01	55.40	0.33	7.25	0.04	0.10	0.01	0.23	0.26	0.00	2.57	0.02	6.89	0.0016	1108
02:30	2.14	0.30	5.39	10.07	0.01	52.40	0.33	7.26	0.03	0.10	0.01	0.25	0.47	0.00	2.44	0.02	6.91	0.0016	1114
03:00	3.33	0.29	6.23	13.84	0.02	54.01	0.31	7.24	0.04	0.15	0.01	0.29	0.64	0.00	2.48	0.01	6.77	0.0018	1102
03:30	1.71	0.28	4.48	8.17	0.02	53.27	0.34	7.25	0.04	0.08	0.01	0.21	0.38	0.00	2.48	0.02	6.89	0.0017	1129
04:00	2.20	0.30	5.08	12.88	0.02	52.05	0.32	7.19	0.04	0.10	0.01	0.24	0.60	0.00	2.41	0.01	6.84	0.0017	1108
04:30	1.57	0.29	6.08	13.35	0.01	54.02	0.32	7.12	0.04	0.07	0.01	0.28	0.60	0.00	2.51	0.02	6.82	0.0017	1098
05:00	2.74	0.27	5.08	11.11	0.01	57.05	0.42	5.04	0.03	0.12	0.01	0.23	0.50	0.00	2.56	0.02	4.80	0.0015	1099
05:30	2.81	0.27	6.19	19.41	0.02	61.22	0.47	2.79	0.06	0.12	0.01	0.26	0.82	0.00	2.59	0.02	2.60	0.0025	1098
06:00	4.06	0.26	4.81	11.63	0.03	61.61	0.48	4.11	0.04	0.18	0.01	0.21	0.50	0.00	2.67	0.02	3.84	0.0016	1118
06:30	2.43	0.25	5.40	18.56	0.01	61.65	0.49	2.92	0.06	0.11	0.01	0.23	0.80	0.00	2.67	0.02	2.71	0.0024	1107
07:00	0.93	0.28	6.16	17.00	0.00	55.28	0.28	7.33	1.66	0.04	0.01	0.28	0.77	0.00	2.50	0.01	6.77	0.0752	1113
07:30	2.20	0.29	5.62	18.99	0.00	53.12	0.30	7.37	1.55	0.10	0.01	0.26	0.87	0.00	2.43	0.01	6.85	0.0711	1127
08:00	2.03	0.26	4.88	16.59	0.01	58.42	0.29	4.87	1.05	0.09	0.01	0.22	0.74	0.00	2.59	0.01	4.53	0.0464	1116
08:30	3.81	0.25	4.79	20.69	0.01	62.05	0.28	3.88	1.90	0.17	0.01	0.21	0.90	0.00	2.69	0.01	3.60	0.0823	1117
09:00	3.49	0.27	7.47	25.52	0.01	59.49	0.27	3.55	0.33	0.15	0.01	0.33	1.11	0.00	2.59	0.01	3.32	0.0142	1111
09:30	5.32	0.25	5.67	11.36	0.01	65.96	0.24	5.49	0.04	0.24	0.01	0.25	0.50	0.00	2.93	0.01	5.16	0.0019	1102
10:00	3.12	0.28	6.33	9.27	0.02	61.04	0.26	3.11	0.04	0.14	0.01	0.28	0.41	0.00	2.69	0.01	2.99	0.0017	1119
10:30	5.19	0.30	9.49	8.41	0.03	63.98	0.32	5.10	0.04	0.23	0.01	0.42	0.37	0.00	2.82	0.01	4.98	0.0017	1108
11:00	9.26	0.30	18.54	17.52	0.16	61.32	0.28	9.92	0.12	0.42	0.01	0.84	0.79	0.01	2.77	0.01	9.49	0.0053	1085
11:30	5.72	0.30	6.55	2.55	0.01	56.54	0.27	7.37	0.04	0.26	0.01	0.30	0.12	0.00	2.57	0.01	6.87	0.0016	1114
12:00	2.92	0.30	4.42	1.86	0.02	54.18	0.27	7.27	0.04	0.13	0.01	0.20	0.08	0.00	2.44	0.01	6.76	0.0016	1123
12:30	3.13	0.30	3.56	0.00	0.02	53.82	0.30	7.07	0.04	0.14	0.01	0.16	0.00	0.00	2.43	0.01	6.76	0.0017	1128
13:00	4.80	0.31	3.65	0.82	0.05	51.54	0.35	6.82	0.05	0.22	0.01	0.16	0.04	0.00	2.31	0.02	6.69	0.0022	1116
13:30	2.98	0.32	5.59	5.31	0.02	52.32	0.33	6.92	0.04	0.13	0.01	0.25	0.24	0.00	2.33	0.01	6.74	0.0018	1077
14:00	3.11	0.31	5.01	3.02	0.05	55.97	0.34	6.82	0.04	0.14	0.01	0.22	0.13	0.00	2.49	0.02	6.69	0.0018	1109
14:30	4.68	0.31	4.72	7.37	0.05	52.89	0.31	6.93	0.04	0.21	0.01	0.21	0.33	0.00	2.40	0.01	6.80	0.0017	1093
15:00	6.12	0.30	4.22	1.42	0.03	52.77	0.32	6.88	0.03	0.28	0.01	0.19	0.06	0.00	2.39	0.01	6.76	0.0016	1108
15:30	4.61	0.29	3.22	0.66	0.06	52.95	0.33	6.96	0.04	0.21	0.01	0.15	0.03	0.00	2.42	0.02	6.83	0.0017	1116
16:00	3.59	0.32	4.38	8.26	0.03	52.03	0.32	6.97	0.07	0.16	0.01	0.20	0.38	0.00	2.37	0.01	6.84	0.0033	1091
16:30	2.12	0.30	5.40	5.88	0.01	54.75	0.29	7.15	0.12	0.09	0.01	0.24	0.26	0.00	2.45	0.01	6.79	0.0055	1100
17:00	3.56	0.26	3.76	5.59	0.00	59.86	0.30	5.86	0.04	0.16	0.01	0.17	0.25	0.00	2.65	0.01	5.59	0.0018	1123
17:30	5.67	0.24	4.37	10.42	0.01	61.64	0.35	5.67	0.04	0.25	0.01	0.19	0.46	0.00	2.72	0.02	5.46	0.0017	1140
18:00	5.73	0.24	3.89	7.36	0.03	60.89	0.31	5.62	0.04	0.25	0.01	0.17	0.32	0.00	2.68	0.01	5.50	0.0017	1142
18:30	4.74	0.24	4.38	8.10	0.03	62.46	0.25	4.97	0.04	0.21	0.01	0.20	0.36	0.00	2.80	0.01	4.87	0.0016	1123
19:00	27.70	3.06	4.86	8.03	0.03	59.49	0.31	7.09	0.08	1.29	0.14	0.23	0.38	0.00	2.78	0.01	6.94	0.0039	1106
19:30	3.88	0.29	4.31	2.34	0.01	54.42	0.30	7.03	0.04	0.18	0.01	0.20	0.11	0.00	2.50	0.01	6.84	0.0017	1087
20:00	4.38	0.30	3.72	0.80	0.01	55.90	0.29	6.93	0.04	0.19	0.01	0.16	0.04	0.00	2.47	0.01	6.58	0.0016	1121
20:30	5.40	0.31	2.89	1.13	0.01	46.02	0.33	6.88	0.04	0.24	0.01	0.13	0.05	0.00	2.02	0.01	6.49	0.0016	1139
21:00	1.94	0.29	2.75	1.95	0.00	52.53	0.32	7.01	0.03	0.09	0.01	0.12	0.09	0.00	2.38	0.01	6.70	0.0013	1146
21:30	1.25	0.29	2.46	0.23	0.00	55.14	0.27	6.96	0.04	0.06	0.01	0.11	0.01	0.00	2.45	0.01	6.56	0.0016	1106
22:00	2.48	0.30	2.65	1.07	0.01	53.16	0.32	7.04	0.04	0.11	0.01	0.12	0.05	0.00	2.39	0.01	6.65	0.0017	1131
22:30	2.05	0.28	3.32	2.43	0.00	54.98	0.30	7.10	0.03	0.10	0.01	0.15	0.11	0.00	2.55	0.01	6.84	0.0016	1131
23:00	2.92	0.29	4.64	8.05	0.01	50.22	0.29	7.11	0.04	0.13	0.01	0.21	0.37	0.00	2.31	0.01	6.87	0.0016	1119
23:30	3.75	0.30	5.31	4.78	0.00	55.45	0.30	7.19	0.04	0.17	0.01	0.24	0.22	0.00	2.51	0.01	6.77	0.0016	1113
00:00	3.59	0.29	3.32	0.99	0.01	49.61	0.34	6.91	0.04	0.16	0.01	0.14	0.04	0.00	2.16	0.01	6.49	0.0016	1124
Min	0.93	0.24	2.46	0.00	0.00	46.02	0.24	2.79	0.03	0.04	0.01	0.11	0.00	0.00	2.02	0.01	2.60	0.0013	1077
Max	27.70	3.06	18.54	25.52	0.16	65.96	0.49	9.92	1.90	1.29	0.14	0.84	1.11	0.01	2.93	0.02	9.49	0.0823	1146
Flux moyen (kg/h)	3.98	0.35	5.12	8.40	0.02	55.88	0.32	6.38	0.17	8.63	0.75	11.07	18.10	0.04	120.64	0.69	292.86	0.3737	1113
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.