

	mesures corrigées à 11% d'O2-IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	Res1	Hg	T2S
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	mg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400		0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	25	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	4.07	0.28	3.57	2.90	0.04	52.34	0.22	6.87	0.04	0.19	0.01	0.16	0.13	0.00	2.38	0.01	6.74	0.0017	1115
01:00	4.35	0.31	5.23	14.24	0.03	51.54	0.22	6.92	0.03	0.20	0.01	0.24	0.65	0.00	2.35	0.01	6.79	0.0014	1104
01:30	2.75	0.28	4.92	7.35	0.04	55.73	0.25	6.96	0.04	0.13	0.01	0.22	0.34	0.00	2.55	0.01	6.82	0.0017	1120
02:00	2.64	0.28	3.65	6.77	0.05	51.51	0.27	6.91	0.04	0.12	0.01	0.17	0.31	0.00	2.35	0.01	6.78	0.0017	1123
02:30	4.22	0.29	4.09	6.94	0.03	54.23	0.25	6.99	0.04	0.19	0.01	0.19	0.32	0.00	2.50	0.01	6.86	0.0017	1123
03:00	2.83	0.30	4.79	9.29	0.04	53.22	0.25	6.71	0.03	0.13	0.01	0.21	0.41	0.00	2.38	0.01	6.59	0.0014	1108
03:30	3.32	0.29	4.86	12.54	0.03	52.26	0.25	6.75	0.04	0.15	0.01	0.22	0.56	0.00	2.34	0.01	6.62	0.0017	1098
04:00	5.32	0.34	4.70	3.93	0.02	46.23	0.25	6.54	0.04	0.22	0.01	0.20	0.16	0.00	1.93	0.01	6.20	0.0017	1101
04:30	2.73	0.27	3.22	2.71	0.01	51.47	0.26	6.96	0.04	0.12	0.01	0.14	0.12	0.00	2.28	0.01	6.58	0.0016	1145
05:00	3.39	0.27	2.77	3.76	0.00	56.89	0.41	5.32	0.03	0.14	0.01	0.12	0.16	0.00	2.39	0.02	5.04	0.0013	1132
05:30	3.78	0.25	2.44	5.88	0.00	62.90	0.50	3.59	0.04	0.16	0.01	0.10	0.24	0.00	2.60	0.02	3.41	0.0017	1124
06:00	5.22	0.29	2.39	5.01	0.01	61.02	0.54	4.87	0.04	0.21	0.01	0.10	0.20	0.00	2.49	0.02	4.65	0.0016	1130
06:30	3.71	0.25	2.37	5.04	0.00	64.14	0.46	3.94	0.06	0.16	0.01	0.10	0.21	0.00	2.68	0.02	3.75	0.0024	1129
07:00	14.00	0.71	3.26	5.00	0.00	53.41	0.14	6.90	0.04	0.62	0.03	0.14	0.22	0.00	2.36	0.01	6.58	0.0016	1121
07:30	4.45	0.33	3.08	3.55	0.02	52.88	0.19	6.83	0.04	0.20	0.01	0.14	0.16	0.00	2.36	0.01	6.65	0.0017	1128
08:00	2.73	0.29	3.07	7.44	0.01	53.91	0.18	6.98	0.04	0.12	0.01	0.14	0.34	0.00	2.43	0.01	6.77	0.0017	1123
08:30	4.26	0.30	4.40	12.18	0.02	55.07	0.15	6.99	0.04	0.19	0.01	0.20	0.55	0.00	2.49	0.01	6.78	0.0018	1112
09:00	4.35	0.31	4.27	4.83	0.01	52.87	0.16	6.96	0.03	0.20	0.01	0.19	0.22	0.00	2.39	0.01	6.79	0.0016	1126
09:30	3.90	0.29	4.67	13.04	0.01	51.60	0.18	7.11	0.04	0.18	0.01	0.22	0.61	0.00	2.40	0.01	6.96	0.0017	1121
10:00	2.73	0.30	5.61	9.76	0.00	54.11	0.16	7.05	0.04	0.12	0.01	0.25	0.44	0.00	2.44	0.01	6.75	0.0017	1106
10:30	2.96	0.31	5.31	9.89	0.01	54.77	0.18	7.12	0.04	0.13	0.01	0.24	0.45	0.00	2.48	0.01	6.81	0.0016	1123
11:00	3.33	0.30	5.50	13.86	0.00	52.00	0.17	7.12	0.03	0.15	0.01	0.25	0.63	0.00	2.37	0.01	6.88	0.0013	1099
11:30	3.20	0.30	5.41	7.76	0.00	52.05	0.15	7.19	0.04	0.15	0.01	0.25	0.35	0.00	2.37	0.01	6.86	0.0017	1107
12:00	3.53	0.31	5.78	8.14	0.01	55.91	0.16	7.26	0.04	0.16	0.01	0.27	0.38	0.00	2.59	0.01	6.96	0.0017	1116
12:30	3.35	0.29	4.72	2.50	0.01	51.49	0.18	7.13	0.04	0.16	0.01	0.22	0.12	0.00	2.39	0.01	6.92	0.0017	1123
13:00	6.87	0.29	5.14	8.78	0.02	53.73	0.18	7.19	0.03	0.32	0.01	0.24	0.41	0.00	2.53	0.01	7.05	0.0014	1110
13:30	5.03	0.28	4.73	2.94	0.01	53.92	0.16	7.07	0.04	0.23	0.01	0.22	0.14	0.00	2.50	0.01	6.94	0.0017	1109
14:00	3.62	0.28	3.80	1.39	0.03	52.27	0.25	6.91	0.07	0.16	0.01	0.17	0.06	0.00	2.37	0.01	6.77	0.0031	1132
14:30	4.52	0.29	3.95	6.20	0.03	55.14	0.21	7.15	0.08	0.21	0.01	0.18	0.29	0.00	2.57	0.01	7.00	0.0038	1132
15:00	3.59	0.29	4.63	6.28	0.01	51.21	0.21	7.03	0.03	0.16	0.01	0.21	0.29	0.00	2.33	0.01	6.83	0.0016	1116
15:30	3.50	0.28	4.86	10.26	0.01	55.00	0.20	7.24	0.04	0.16	0.01	0.23	0.48	0.00	2.56	0.01	7.01	0.0017	1128
16:00	4.52	0.28	4.46	4.53	0.02	51.42	0.21	7.11	0.04	0.21	0.01	0.21	0.21	0.00	2.38	0.01	6.94	0.0017	1128
16:30	3.34	0.27	3.44	5.06	0.02	52.86	0.22	7.06	0.04	0.15	0.01	0.16	0.23	0.00	2.43	0.01	6.88	0.0017	1143
17:00	5.64	0.26	3.57	4.44	0.02	57.44	0.24	6.39	0.03	0.26	0.01	0.16	0.20	0.00	2.60	0.01	6.26	0.0015	1122
17:30	5.99	0.26	3.09	7.54	0.03	63.26	0.31	5.97	0.04	0.27	0.01	0.14	0.34	0.00	2.83	0.01	5.84	0.0017	1135
18:00	3.96	0.24	6.30	13.97	0.04	62.07	0.24	3.96	0.04	0.18	0.01	0.28	0.62	0.00	2.77	0.01	3.86	0.0018	1120
18:30	7.07	0.25	5.41	9.69	0.00	59.37	0.17	7.57	0.04	0.32	0.01	0.24	0.43	0.00	2.66	0.01	7.27	0.0017	1125
19:00	2.75	0.27	4.38	0.76	0.01	54.40	0.25	7.29	0.03	0.13	0.01	0.21	0.04	0.00	2.55	0.01	7.01	0.0013	1126
19:30	3.55	0.26	3.93	1.94	0.03	55.06	0.25	7.23	0.04	0.17	0.01	0.18	0.09	0.00	2.59	0.01	7.05	0.0017	1132
20:00	3.47	0.27	4.26	4.84	0.03	53.17	0.26	7.10	0.04	0.16	0.01	0.20	0.23	0.00	2.47	0.01	6.97	0.0017	1134
20:30	3.25	0.29	5.47	8.70	0.01	53.13	0.26	7.13	0.04	0.15	0.01	0.26	0.41	0.00	2.50	0.01	7.00	0.0017	1110
21:00	3.04	0.27	4.12	1.96	0.01	53.86	0.27	6.96	0.03	0.14	0.01	0.19	0.09	0.00	2.48	0.01	6.83	0.0014	1121
21:30	2.91	0.28	3.31	3.32	0.02	52.69	0.25	6.90	0.04	0.13	0.01	0.15	0.15	0.00	2.40	0.01	6.75	0.0018	1133
22:00	2.24	0.29	3.96	9.66	0.01	51.85	0.25	7.00	0.04	0.10	0.01	0.18	0.44	0.00	2.38	0.01	6.81	0.0017	1115
22:30	2.52	0.28	4.32	3.84	0.02	55.53	0.26	7.07	0.04	0.12	0.01	0.20	0.18	0.00	2.56	0.01	6.86	0.0017	1131
23:00	3.33	0.29	3.27	1.11	0.03	50.59	0.23	6.79	0.03	0.15	0.01	0.15	0.05	0.00	2.27	0.01	6.65	0.0014	1109
23:30	3.01	0.34	2.66	0.40	0.00	51.51	0.28	6.58	0.04	0.12	0.01	0.11	0.02	0.00	2.14	0.01	6.12	0.0017	1088
00:00	1.80	0.29	2.50	0.33	0.00	51.87	0.25	6.68	0.04	0.08	0.01	0.10	0.01	0.00	2.17	0.01	6.16	0.0016	1131
Min	1,80	0,24	2,37	0,33	0,00	46,23	0,14	3,59	0,03	0,08	0,01	0,10	0,01	0,00	1,93	0,01	3,41	0,0013	1088
Max	14,00	0,71	6,30	14,24	0,05	64,14	0,54	7,57	0,08	0,62	0,03	0,28	0,65	0,00	2,83	0,02	7,27	0,0038	1145
	3,97	0,29	4,16	6,30	0,02	54,27	0,24	6,69	0,04	8,58	0,64	9,04	13,68	0,04	117,32	0,52	311,40	0,0823	1121
Données moyennées																			

[illegible]**Commentaires :**

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.