

Paramètre	mesures corrigées à 11% d'O2 -IC 95%									Flux massique										Process
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S	
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C	
VLE 30 min		20	60	200	30	400	30	0												
VLE max	100	20			150															
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00		
Seuils min																			850	
00:30	0.58	0.04	4.24	11.35	0.03	61.24	1.15	5.96	0.00	0.02	0.00	0.17	0.46	0.00	2.47	0.05	5.44	0.0000	1148	
01:00	0.99	0.08	4.42	9.20	0.01	63.27	1.13	5.96	0.03	0.04	0.00	0.18	0.37	0.00	2.55	0.05	5.44	0.0011	1146	
01:30	0.58	0.18	4.52	11.55	0.02	61.64	1.17	5.99	0.04	0.02	0.01	0.18	0.47	0.00	2.50	0.05	5.47	0.0016	1162	
02:00	0.28	0.20	4.80	14.89	0.02	60.87	1.15	6.04	0.04	0.01	0.01	0.20	0.61	0.00	2.47	0.05	5.51	0.0016	1147	
02:30	0.13	0.16	4.26	10.26	0.01	61.70	1.19	6.01	0.00	0.01	0.01	0.17	0.42	0.00	2.51	0.05	5.48	0.0000	1134	
03:00	1.40	0.17	3.73	9.89	0.02	64.92	1.04	5.96	0.02	0.06	0.01	0.15	0.40	0.00	2.62	0.04	5.44	0.0010	1147	
03:30	1.50	0.13	4.15	9.97	0.03	57.37	0.85	5.61	0.04	0.06	0.00	0.16	0.38	0.00	2.19	0.03	5.12	0.0016	1119	
04:00	0.76	0.13	4.29	13.77	0.02	61.37	0.69	5.95	0.04	0.03	0.01	0.17	0.56	0.00	2.47	0.03	5.43	0.0016	1126	
04:30	0.71	0.18	5.63	13.72	0.01	62.87	0.63	5.69	0.00	0.03	0.01	0.22	0.53	0.00	2.43	0.02	5.19	0.0000	1131	
05:00	1.08	0.34	3.83	6.41	0.00	55.51	0.62	5.37	0.03	0.04	0.01	0.14	0.23	0.00	1.96	0.02	4.77	0.0010	1113	
05:30	0.16	0.14	4.08	10.00	0.00	66.92	0.57	5.68	0.04	0.01	0.01	0.15	0.37	0.00	2.50	0.02	5.07	0.0015	1128	
06:00	0.89	0.13	4.91	11.92	0.02	62.76	0.66	2.81	0.11	0.03	0.01	0.19	0.46	0.00	2.44	0.03	2.56	0.0045	1151	
06:30	1.09	0.11	4.87	9.68	0.03	60.53	0.62	3.20	0.12	0.04	0.00	0.19	0.37	0.00	2.31	0.02	2.93	0.0047	1126	
07:00	2.04	0.13	4.91	14.57	0.02	56.00	0.57	4.31	4.55	0.08	0.01	0.20	0.59	0.00	2.26	0.02	3.93	0.1841	1141	
07:30	0.80	0.16	5.27	13.76	0.05	69.57	0.68	0.67	1.02	0.03	0.01	0.21	0.54	0.00	2.72	0.03	0.61	0.0400	1137	
08:00	1.55	0.19	4.59	8.92	0.03	65.05	0.76	1.41	0.04	0.06	0.01	0.17	0.34	0.00	2.48	0.03	1.29	0.0016	1103	
08:30	0.99	0.20	4.99	12.14	0.02	60.59	0.70	0.88	0.00	0.04	0.01	0.19	0.47	0.00	2.33	0.03	0.80	0.0000	1097	
09:00	1.92	0.24	5.61	10.81	0.06	56.28	0.68</													

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.