

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	0.05	0.22	4.82	9.89	0.00	61.98	0.74	0.00	0.00	0.00	0.01	0.19	0.38	0.00	2.40	0.03	0.00	0.0000	1132
01:00	1.35	0.25	5.03	9.43	0.00	62.07	0.79	1.10	0.03	0.05	0.01	0.19	0.36	0.00	2.38	0.03	1.01	0.0010	1132
01:30	0.44	0.21	5.11	11.19	0.00	60.62	0.58	0.17	0.04	0.02	0.01	0.20	0.44	0.00	2.40	0.02	0.16	0.0016	1141
02:00	1.01	0.21	5.54	9.42	0.00	63.41	0.58	0.92	0.05	0.04	0.01	0.21	0.36	0.00	2.45	0.02	0.84	0.0018	1133
02:30	0.37	0.22	5.33	9.25	0.00	62.18	0.72	0.22	0.02	0.01	0.01	0.20	0.35	0.00	2.37	0.03	0.20	0.0007	1114
03:00	0.94	0.23	3.71	3.60	0.00	61.94	0.69	0.58	0.03	0.04	0.01	0.15	0.14	0.00	2.43	0.03	0.53	0.0010	1143
03:30	0.34	0.21	4.83	9.64	0.00	59.87	0.66	0.05	0.04	0.01	0.01	0.19	0.38	0.00	2.34	0.03	0.04	0.0015	1147
04:00	0.05	0.21	4.66	8.37	0.00	61.97	0.63	0.00	0.04	0.00	0.01	0.18	0.33	0.00	2.45	0.02	0.00	0.0015	1141
04:30	0.05	0.22	5.36	8.99	0.00	61.59	0.60	0.00	0.00	0.00	0.01	0.21	0.35	0.00	2.38	0.02	0.00	0.0000	1135
05:00	1.20	0.27	4.63	6.18	0.00	61.38	0.58	0.93	0.03	0.05	0.01	0.18	0.24	0.00	2.36	0.02	0.84	0.0010	1120
05:30	0.10	0.22	4.68	8.08	0.00	64.38	0.72	0.00	0.04	0.00	0.01	0.18	0.32	0.00	2.53	0.03	0.00	0.0016	1150
06:00	0.07	0.24	4.90	8.62	0.00	59.58	0.65	0.00	0.04	0.00	0.01	0.18	0.32	0.00	2.23	0.02	0.00	0.0016	1138
06:30	0.13	0.15	5.33	11.26	0.00	61.68	0.60	2.71	0.00	0.01	0.01	0.21	0.45	0.00	2.46	0.02	2.48	0.0000	1149
07:00	0.87	0.08	4.10	6.79	0.00	61.54	0.54	5.85	0.91	0.03	0.00	0.16	0.27	0.00	2.44	0.02	5.34	0.0359	1134
07:30	0.06	0.05	4.34	9.63	0.00	59.85	0.60	5.79	0.00	0.00	0.00	0.17	0.38	0.00	2.36	0.02	5.28	0.0000	1130
08:00	0.00	0.06	4.56	7.31	0.00	52.73	0.57	5.65	1.40	0.00	0.00	0.17	0.28	0.00	2.00	0.02	5.09	0.0532	1123
08:30	0.01	0.04	4.24	7.51	0.00	61.82	0.62	5.78	0.00	0.00	0.00	0.16	0.29	0.00	2.37	0.02	5.16	0.0000	1133
09:00																			
09:30																			
10:00																			
10:30	1.70	0.23	2.38	1.67	0.00	28.94	1.17	5.65	0.00	0.05	0.01	0.07	0.05	0.00	0.86	0.03	3.97	0.0000	1141
11:00	26.58	0.44	2.74	5.61	0.00	43.23	1.12	6.10	0.02	0.84	0.01	0.09	0.18	0.00	1.36	0.04	4.29	0.0008	1166
11:30	2.34	0.10	5.91	13.77	0.00	44.06	1.10	6.02	0.04	0.07	0.00	0.18	0.41	0.00	1.32	0.03	4.05	0.0012	1149
12:00	2.53	0.07	4.38	7.48	0.00	47.01	1.16	6.08	0.04	0.07	0.00	0.13	0.22	0.00	1.37	0.03	3.93	0.0011	1160
12:30	2.97	0.08	4.60	7.98	0.00	44.26	1.29	6.14	0.00	0.09	0.00	0.13	0.23	0.00	1.29	0.04	3.95	0.0000	1172
13:00	3.07	0.14	4.10	6.11	0.00	37.70	1.41	6.19	0.02	0.09	0.00	0.12	0.18	0.00	1.11	0.04	3.98	0.0007	1160
13:30	1.86	0.08	4.08	6.59	0.00	47.04	1.64	6.04	0.04	0.05	0.00	0.12	0.19	0.00	1.37	0.05	3.95	0.0012	1162
14:00	1.13	0.09	4.11	7.40	0.00	48.45	1.84	5.78	0.04	0.03	0.00	0.12	0.22	0.00	1.43	0.05	4.00	0.0012	1176
14:30	14.57	0.09	6.14	15.57	0.00	41.58	1.69	5.93	0.00	0.43	0.00	0.18	0.46	0.00	1.22	0.05	3.98	0.0000	1139
15:00	9.01	0.11	4.56	11.45	0.00	42.70	1.64	6.11	0.03	0.27	0.00	0.14	0.34	0.00	1.27	0.05	4.05	0.0007	1143
15:30	1.86	0.06	5.32	10.94	0.00	49.74	1.77	6.15	0.04	0.06	0.00	0.17	0.35	0.00	1.60	0.06	4.40	0.0013	1136
16:00	0.04	0.05	4.58	6.69	0.00	62.85	1.94	6.10	0.04	0.00	0.00	0.16	0.23	0.00	2.18	0.07	4.77	0.0014	1140
16:30	0.30	0.06	4.81	10.56	0.00	61.49	1.75	6.31	0.00	0.01	0.00	0.18	0.40	0.00	2.30	0.07	5.10	0.0000	1167
17:00	0.48	0.07	4.81	13.46	0.00	56.56	1.65	6.42	0.02	0.02	0.00	0.19	0.53	0.00	2.23	0.06	5.34	0.0010	1172
17:30	0.07	0.03	6.22	17.57	0.00	61.12	1.52	6.46	0.04	0.00	0.00	0.25	0.71	0.00	2.45	0.06	5.48	0.0015	1169
18:00	0.20	0.14	5.04	9.84	0.00	61.90	1.48	3.11	0.04	0.01	0.01	0.20	0.39	0.00	2.47	0.06	2.66	0.0015	1165
18:30	0.28	0.17	4.46	13.97	0.00	60.49	1.25	3.14	0.00	0.01	0.01	0.18	0.56	0.00	2.43	0.05	2.71	0.0000	1167
19:00	0.45	0.11	5.21	20.56	0.00	59.58	1.17	6.24	0.02	0.02	0.00	0.20	0.80	0.00	2.31	0.05	5.29	0.0009	1137
19:30	0.08	0.08	3.18	5.61	0.00	63.46	1.15	6.07	0.04	0.00	0.00	0.13	0.22	0.00	2.52	0.05	5.38	0.0015	1143
20:00	1.69	0.10	3.10	6.96	0.00	62.63	1.10	5.95	0.04	0.06	0.00	0.12	0.27	0.00	2.41	0.04	5.22	0.0015	1116
20:30	0.33	0.14	5.28	23.30	0.00	55.13	1.05	6.13	0.00	0.01	0.01	0.20	0.90	0.00	2.13	0.04	5.22	0.0000	1110
21:00	0.37	0.18	5.35	12.67	0.00	64.50	1.06	6.07	0.03	0.01	0.01	0.21	0.49	0.00	2.48	0.04	5.24	0.0010	1124
21:30	0.03	0.11	4.07	8.23	0.00	61.08	1.11	6.10	0.04	0.00	0.00	0.16	0.33	0.00	2.42	0.04	5.38	0.0015	1140
22:00	0.07	0.08	4.06	11.40	0.00	60.77	1.13	6.04	0.04	0.00	0.00	0.16	0.45	0.00	2.41	0.04	5.40	0.0015	1131
22:30	0.20	0.11	6.37	19.17	0.00	60.98	1.09	6.04	0.00	0.01	0.00	0.25	0.74	0.00	2.37	0.04	5.30	0.0000	1114
23:00	0.53	0.13	5.99	14.90	0.00	62.71	1.08	6.15	0.02	0.02	0.01	0.24	0.59	0.00	2.50	0.04	5.44	0.0010	1127
23:30	0.32	0.06	4.14	9.96	0.00	61.67	1.12	6.10	0.04	0.01	0.00	0.17	0.40	0.00	2.47	0.04	5.45	0.0015	1120
00:00	0.16	0.05	4.21	11.12	0.00	61.81	1.08	6.00	0.04	0.01	0.00	0.17	0.44	0.00	2.46	0.04	5.41	0.0015	1117
Min	0,00	0,03	1,56	1,64	0,00	15,27	0,31	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,0000	899
Max	283,46	22,77	6,37	23,30	0,02	78,23	1,94	6,46	1,40	0,84	0,01	0,25	0,90	0,00	2,53	0,07	5,48	0,0532	1176
Flux moyen (kg/h)	1,78	0,14	4,68	10,13	0,00	56,71	1,08	4,32	0,07	2,55	0,23	7,75	16,92	0,00	95,07	1,74	156,29	0,1279	1141
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.

9h à 10h test sécurité chaudière