

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	0.54	0.04	3.17	6.11	0.00	61.48	1.12	6.05	0.00	0.02	0.00	0.13	0.25	0.00	2.48	0.05	5.48	0.0000	1122
01:00	2.11	0.08	3.69	10.67	0.00	63.76	1.08	6.13	0.02	0.09	0.00	0.15	0.44	0.00	2.62	0.04	5.58	0.0010	1127
01:30	0.50	0.03	3.68	9.54	0.00	63.61	0.94	6.03	0.04	0.02	0.00	0.15	0.39	0.00	2.58	0.04	5.50	0.0016	1139
02:00	0.71	0.03	3.61	8.26	0.00	58.61	0.80	5.75	0.04	0.03	0.00	0.14	0.32	0.00	2.28	0.03	5.25	0.0016	1122
02:30	0.49	0.05	5.00	15.37	0.00	60.93	0.67	5.76	0.00	0.02	0.00	0.19	0.60	0.00	2.37	0.03	5.24	0.0000	1112
03:00	0.60	0.11	5.69	13.07	0.00	60.85	0.61	5.79	0.03	0.02	0.00	0.22	0.50	0.00	2.34	0.02	5.18	0.0010	1091
03:30	0.05	0.06	3.66	6.97	0.00	59.94	0.59	5.87	0.04	0.00	0.00	0.14	0.27	0.00	2.31	0.02	5.20	0.0015	1109
04:00	0.85	0.06	5.23	16.59	0.00	57.03	0.55	6.13	0.04	0.03	0.00	0.20	0.64	0.00	2.20	0.02	5.17	0.0014	1125
04:30	0.93	0.06	3.89	7.34	0.00	63.74	0.50	6.11	0.00	0.04	0.00	0.15	0.28	0.00	2.44	0.02	5.14	0.0000	1119
05:00	0.36	0.08	3.62	6.90	0.00	64.26	0.51	6.14	0.02	0.01	0.00	0.14	0.27	0.00	2.53	0.02	5.33	0.0009	1143
05:30	0.01	0.03	4.50	10.95	0.00	61.33	0.53	6.08	0.04	0.00	0.00	0.18	0.44	0.00	2.45	0.02	5.40	0.0015	1141
06:00	0.35	0.15	5.30	11.64	0.00	58.62	0.61	2.94	0.04	0.01	0.01	0.20	0.45	0.00	2.25	0.02	2.61	0.0016	1107
06:30	32.79	0.17	5.60	20.23	0.00	73.03	0.56	34.66	0.00	1.26	0.01	0.22	0.78	0.00	2.81	0.02	29.69	0.0000	1116
07:00	0.60	0.07	3.56	8.79	0.00	69.39	0.54	6.12	0.02	0.02	0.00	0.14	0.35	0.00	2.74	0.02	5.41	0.0009	1130
07:30	0.50	0.06	5.06	13.48	0.00	60.40	0.50	5.99	0.04	0.02	0.00	0.20	0.54	0.00	2.42	0.02	5.45	0.0016	1122
08:00	0.15	0.05	4.16	10.21	0.00	59.81	0.48	5.96	0.04	0.01	0.00	0.17	0.41	0.00	2.40	0.02	5.44	0.0016	1138
08:30	0.42	0.05	5.07	11.87	0.00	62.48	0.49	5.85	0.00	0.02	0.00	0.20	0.47	0.00	2.47	0.02	5.34	0.0000	1097
09:00	3.65	0.10	4.31	9.57	0.00	61.41	0.50	5.91	0.03	0.14	0.00	0.17	0.38	0.00	2.43	0.02	5.39	0.0010	1111
09:30	1.48	0.07	4.21	8.54	0.00	61.75	0.48	6.01	0.04	0.06	0.00	0.17	0.34	0.00	2.47	0.02	5.48	0.0016	1111
10:00	2.96	0.09	5.29	13.58	0.00	62.91	0.45	5.99	0.04	0.12	0.00	0.21	0.54	0.00	2.49	0.02	5.41	0.0015	1098
10:30	0.78	0.10	6.49	16.84	0.00	62.68	0.46	5.94	0.00	0.03	0.00	0.26	0.66	0.00	2.47	0.02	5.35	0.0000	1117
11:00	1.35	0.16	10.37	23.17	0.00	58.49	0.44	6.17	0.02	0.06	0.01	0.42	0.94	0.00	2.38	0.02	5.56	0.0010	1127
11:30	0.81	0.11	7.85	14.40	0.00	65.22	0.44	6.06	0.04	0.03	0.00	0.32	0.59	0.00	2.65	0.02	5.52	0.0016	1146
12:00	1.16	0.13	5.06	7.99	0.00	51.36	0.44	5.81	0.04	0.05	0.01	0.20	0.31	0.00	2.00	0.02	5.28	0.0016	1126
12:30	0.49	0.15	7.60	17.90	0.00	57.51	0.44	5.74	0.00	0.02	0.01	0.29	0.67	0.00	2.16	0.02	5.09	0.0000	1095
13:00	0.56	0.17	5.13	8.27	0.00	62.42	0.49	5.72	0.03	0.02	0.01	0.19	0.30	0.00	2.25	0.02	4.91	0.0009	1107
13:30	0.37	0.11	5.30	10.87	0.00	61.46	0.52	5.87	0.04	0.01	0.00	0.20	0.41	0.00	2.29	0.02	5.05	0.0015	1143
14:00	0.41	0.12	4.39	12.95	0.00	59.73	0.67	5.65	0.04	0.01	0.00	0.16	0.47	0.00	2.16	0.02	4.93	0.0015	1126
14:30	0.52	0.15	6.18	29.61	0.00	61.44	0.68	5.85	0.00	0.02	0.01	0.22	1.05	0.00	2.19	0.02	4.84	0.0000	1118
15:00	0.59	0.15	4.61	10.20	0.00	63.54	0.76	5.97	0.02	0.02	0.01	0.17	0.37	0.00	2.31	0.03	4.96	0.0009	1141
15:30	0.00	0.08	3.67	22.19	0.00	60.00	0.82	5.96	0.04	0.00	0.00	0.23	0.80	0.00	2.17	0.03	4.92	0.0014	1126
16:00	12.37	0.38	5.50	17.95	0.00	59.30	0.87	6.02	0.04	0.44	0.01	0.19	0.63	0.00	2.10	0.03	4.82	0.0014	1124
16:30	0.13	0.08	6.20	21.71	0.00	59.79	0.94	6.01	0.00	0.00	0.00	0.22	0.76	0.00	2.10	0.03	4.79	0.0000	1127
17:00	2.93	0.12	8.78	38.60	0.00	58.86	1.00	6.12	0.02	0.10	0.00	0.31	1.38	0.00	2.11	0.04	4.91	0.0009	1120
17:30	0.34	0.08	6.30	22.37	0.00	61.50	1.00	6.06	0.04	0.01	0.00	0.22	0.79	0.00	2.17	0.04	4.81	0.0014	1136
18:00	0.52	0.19	6.02	12.84	0.00	59.64	0.99	3.01	0.04	0.02	0.01	0.21	0.45	0.00	2.07	0.03	2.44	0.0014	1142
18:30	3.14	0.25	5.11	10.31	0.00	57.45	1.00	5.44	0.00	0.11	0.01	0.17	0.35	0.00	1.97	0.03	4.38	0.0000	1131
19:00	0.55	0.14	5.51	13.62	0.00	59.20	1.17	5.85	0.02	0.02	0.00	0.19	0.47	0.00	2.05	0.04	4.71	0.0009	1127
19:30	0.04	0.09	4.04	4.10	0.00	63.07	1.23	5.73	0.04	0.00	0.00	0.14	0.14	0.00	2.17	0.04	4.65	0.0014	1127
20:00	0.04	0.11	2.61	2.08	0.00	61.00	1.20	5.75	0.04	0.00	0.00	0.09	0.07	0.00	2.11	0.04	4.69	0.0014	1120
20:30	0.58	0.18	2.45	3.10	0.00	61.21	1.18	5.80	0.00	0.02	0.01	0.08	0.11	0.00	2.12	0.04	4.70	0.0000	1124
21:00	0.45	0.27	3.67	10.51	0.00	62.19	1.21	5.97	0.02	0.02	0.01	0.13	0.38	0.00	2.24	0.04	4.92	0.0009	1135
21:30	0.44	0.15	5.15	19.85	0.00	59.32	1.17	5.98	0.04	0.02	0.01	0.19	0.72	0.00	2.15	0.04	4.93	0.0014	1132
22:00	0.00	0.06	4.65	11.54	0.00	62.23	1.21	5.84	0.04	0.00	0.00	0.17	0.41	0.00	2.22	0.04	4.85	0.0014	1132
22:30	0.11	0.05	3.67	6.61	0.00	62.44	1.23	5.91	0.00	0.00	0.00	0.14	0.24	0.00	2.31	0.05	5.01	0.0000	1142
23:00	0.47	0.16	4.50	17.17	0.00	65.99	1.16	6.04	0.03	0.02	0.01	0.17	0.67	0.00	2.56	0.05	5.29	0.0010	1140
23:30	0.05	0.12	4.86	22.45	0.00	60.59	0.87	6.12	0.04	0.00	0.00	0.19	0.88	0.00	2.38	0.03	5.36	0.0015	1127
00:00	3.65	0.09	3.66	21.08	0.00	57.75	0.73	6.16	0.04	0.15	0.00	0.15	0.84	0.00	2.31	0.03	5.43	0.0016	1127
Min	0.00	0.03	2.45	2.08	0.00	51.36	0.44	2.94	0.00	0.00	0.00	0.08	0.07	0.00	1.97	0.02	2.44	0.0000	1091
Max	32.79	0.38	10.37	38.60	0.00	73.03	1.23	34.66	0.04	1.26	0.01	0.42	1.38	0.00	2.81	0.05	29.69	0.0016	1146
Flux moyen (kg/h)	1.73	0.11	5.01	13.54	0.00	61.27	0.77	5.81	0.03	3.15	0.20	9.08	24.53	0.00	111.26	1.38	265.78	0.0471	1124
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.