

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	1.24	0.22	3.29	3.21	0.00	63.85	0.68	1.17	0.00	0.05	0.01	0.13	0.13	0.00	2.53	0.03	1.07	0.0000	1118
01:00	2.08	0.23	4.47	11.27	0.00	60.06	0.70	1.98	0.04	0.08	0.01	0.18	0.45	0.00	2.38	0.03	1.80	0.0015	1115
01:30	2.06	0.23	4.99	13.64	0.00	62.71	0.75	1.98	0.00	0.08	0.01	0.20	0.55	0.00	2.51	0.03	1.80	0.0000	1130
02:00	1.30	0.22	4.73	12.45	0.00	61.76	0.70	1.25	0.00	0.05	0.01	0.19	0.50	0.00	2.48	0.03	1.14	0.0000	1135
02:30	1.82	0.24	6.48	23.65	0.00	61.76	0.81	1.72	0.00	0.07	0.01	0.26	0.93	0.00	2.43	0.03	1.57	0.0000	1113
03:00	0.99	0.23	10.62	21.15	0.00	61.79	0.82	0.94	0.00	0.04	0.01	0.42	0.84	0.00	2.45	0.03	0.85	0.0000	1118
03:30	2.42	0.23	5.12	12.58	0.00	65.04	0.75	2.33	0.00	0.10	0.01	0.21	0.51	0.00	2.62	0.03	2.13	0.0000	1147
04:00	1.90	0.22	5.51	13.13	0.00	61.06	0.82	1.81	0.00	0.08	0.01	0.22	0.52	0.00	2.44	0.03	1.65	0.0000	1132
04:30	1.49	0.25	7.89	19.68	0.00	59.46	0.78	1.41	0.00	0.06	0.01	0.31	0.77	0.00	2.34	0.03	1.28	0.0000	1120
05:00	2.41	0.25	5.85	11.39	0.00	62.15	0.70	2.26	0.00	0.09	0.01	0.23	0.45	0.00	2.45	0.03	2.06	0.0000	1120
05:30	2.65	0.25	5.26	10.28	0.00	63.54	0.81	2.51	0.00	0.11	0.01	0.21	0.41	0.00	2.52	0.03	2.29	0.0000	1125
06:00	2.73	0.23	5.17	11.79	0.00	60.99	0.72	2.56	0.00	0.11	0.01	0.20	0.46	0.00	2.39	0.03	2.34	0.0000	1115
06:30	1.30	0.13	4.63	9.61	0.00	59.55	0.55	3.71	0.00	0.05	0.01	0.18	0.38	0.00	2.36	0.02	3.38	0.0000	1121
07:00	0.43	0.03	4.15	8.16	0.00	62.37	0.40	5.79	0.00	0.02	0.00	0.16	0.32	0.00	2.43	0.02	5.24	0.0000	1108
07:30	0.98	0.02	2.08	2.12	0.00	60.61	0.43	5.97	0.00	0.04	0.00	0.08	0.08	0.00	2.43	0.02	5.39	0.0000	1129
08:00	26.73	3.23	1.72	7.09	0.00	62.20	0.43	6.03	4.07	1.07	0.13	0.07	0.28	0.00	2.49	0.02	5.39	0.1631	1135
08:30	0.30	0.06	3.85	17.52	0.00	62.44	0.42	6.09	4.23	0.01	0.00	0.16	0.71	0.00	2.54	0.02	5.50	0.1722	1147
09:00	30.58	1.78	8.01	39.57	0.00	57.21	0.41	6.18	0.44	1.26	0.07	0.33	1.63	0.00	2.36	0.02	5.58	0.0182	1136
09:30	7.42	0.09	8.68	22.05	0.00	75.91	0.42	6.24	0.23	0.31	0.00	0.36	0.92	0.00	3.15	0.02	5.64	0.0097	1137
10:00	1.38	0.00	4.70	9.94	0.00	61.92	0.44	6.13	0.01	0.06	0.00	0.19	0.41	0.00	2.54	0.02	5.59	0.0003	1140
10:30	2.88	0.00	3.98	6.51	0.00	61.33	0.43	6.03	0.00	0.12	0.00	0.16	0.26	0.00	2.46	0.02	5.50	0.0000	1140
11:00	2.34	0.00	3.42	4.80	0.00	61.96	0.46	5.94	0.00	0.09	0.00	0.14	0.19	0.00	2.45	0.02	5.42	0.0000	1133
11:30	2.30	0.00	3.96	6.07	0.00	59.50	0.45	5.95	0.00	0.09	0.00	0.16	0.24	0.00	2.36	0.02	5.44	0.0000	1141
12:00	1.38	0.00	5.35	12.21	0.00	62.17	0.44	6.01	0.00	0.06	0.00	0.21	0.49	0.00	2.48	0.02	5.49	0.0000	1138
12:30	1.53	0.00	4.26	4.57	0.00	63.08	0.43	5.90	0.39	0.06	0.00	0.17	0.18	0.00	2.49	0.02	5.39	0.0155	1136
13:00	2.98	0.00	4.17	8.86	0.00	60.05	0.44	5.83	0.21	0.12	0.00	0.16	0.35	0.00	2.34	0.02	5.33	0.0083	1113
13:30	2.80	0.00	3.53	4.87	0.00	61.23	0.43	5.67	0.02	0.11	0.00	0.13	0.18	0.00	2.32	0.02	5.18	0.0008	1135
14:00	2.52	0.17	5.17	13.64	0.00	63.49	0.61	2.45	0.00	0.09	0.01	0.20	0.51	0.00	2.39	0.02	2.23	0.0000	1136
14:30	2.93	0.20	6.88	14.92	0.00	66.68	0.52	2.64	0.00	0.11	0.01	0.26	0.56	0.00	2.52	0.02	2.41	0.0000	1091
15:00	2.52	0.20	6.80	11.24	0.00	60.82	0.64	2.28	0.00	0.10	0.01	0.26	0.43	0.00	2.30	0.02	2.08	0.0000	1088
15:30	3.08	0.21	4.21	6.93	0.00	63.47	0.52	2.79	0.00	0.12	0.01	0.16	0.26	0.00	2.40	0.02	2.54	0.0000	1102
16:00	2.39	0.19	8.04	18.59	0.00	58.15	0.46	2.23	0.00	0.09	0.01	0.31	0.73	0.00	2.27	0.02	2.04	0.0000	1102
16:30	2.00	0.20	10.07	19.93	0.00	58.03	0.42	1.84	0.00	0.08	0.01	0.39	0.77	0.00	2.23	0.02	1.67	0.0000	1096
17:00	1.54	0.20	11.60	18.94	0.00	62.56	0.45	1.43	0.00	0.06	0.01	0.45	0.73	0.00	2.41	0.02	1.29	0.0000	1105
17:30	1.50	0.21	10.86	21.24	0.00	64.92	0.37	1.40	0.00	0.06	0.01	0.42	0.82	0.00	2.49	0.01	1.24	0.0000	1114
18:00	1.19	0.20	10.77	20.43	0.00	60.76	0.46	1.05	0.00	0.05	0.01	0.41	0.78	0.00	2.32	0.02	0.95	0.0000	1123
18:30	1.95	0.09	4.05	7.86	0.00	59.06	0.60	4.24	0.00	0.08	0.00	0.16	0.31	0.00	2.36	0.02	3.87	0.0000	1139
19:00	1.48	0.00	4.48	12.13	0.00	61.20	0.45	5.90	0.00	0.06	0.00	0.18	0.48	0.00	2.43	0.02	5.38	0.0000	1133
19:30	1.15	0.02	4.60	9.83	0.00	63.21	0.44	5.92	0.00	0.05	0.00	0.18	0.39	0.00	2.50	0.02	5.40	0.0000	1113
20:00	0.94	0.09	5.46	11.48	0.00	59.28	0.52	4.14	0.00	0.04	0.00	0.21	0.45	0.00	2.30	0.02	3.74	0.0000	1094
20:30	30.12	0.27	5.32	10.47	0.00	64.28	0.76	28.21	0.00	1.16	0.01	0.21	0.40	0.00	2.48	0.03	25.33	0.0000	1115
21:00	2.15	0.20	7.05	9.20	0.00	60.84	0.66	2.01	0.00	0.08	0.01	0.28	0.36	0.00	2.38	0.03	1.84	0.0000	1119
21:30	2.45	0.19	2.19	1.07	0.00	63.58	0.79	2.29	0.00	0.10	0.01	0.09	0.04	0.00	2.48	0.03	2.09	0.0000	1135
22:00	1.96	0.19	1.31	1.41	0.00	60.11	0.87	1.81	0.00	0.08	0.01	0.05	0.05	0.00	2.33	0.03	1.66	0.0000	1128
22:30	2.16	0.20	1.21	3.61	0.00	64.53	0.82	2.00	0.00	0.08	0.01	0.05	0.14	0.00	2.50	0.03	1.82	0.0000	1123
23:00	2.78	0.21	3.93	15.35	0.00	59.56	0.93	2.57	0.00	0.11	0.01	0.15	0.59	0.00	2.31	0.04	2.35	0.0000	1113
23:30	2.63	0.21	5.41	14.97	0.00	65.24	0.75	2.85	0.00	0.10	0.01	0.21	0.57	0.00	2.48	0.03	2.60	0.0000	1098
00:00	2.66	0.22	5.33	11.72	0.00	57.89	0.81	2.40	0.00	0.10	0.01	0.20	0.44	0.00	2.19	0.03	2.19	0.0000	1095
Min	0,30	0,00	1,21	1,07	0,00	57,21	0,37	0,94	0,00	0,01	0,00	0,05	0,04	0,00	2,19	0,01	0,85	0,0000	1088
Max	30,58	3,23	11,60	39,57	0,00	75,91	0,93	28,21	4,23	1,26	0,13	0,45	1,63	0,00	3,15	0,04	25,33	0,1722	1147
Flux moyen (g/h)	3,76	0,25	5,43	12,15	0,00	61,94	0,59	3,48	0,20	7,15	0,47	10,22	22,96	0,00	116,84	1,12	174,16	0,3897	1122
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.