

UVE	Mesures corrigées à 11% d'O ₂ - IC 95%						Flux massique en kg							Process
Ligne 1	HCl	SO ₂	NO _x	COT	NH ₃	Poussières	Q-HCL	Q-CO	Q-SO ₂	Q-NO _x	Q-COT	Q-NH ₃	Q-Pouss	T2S
Unité	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	kg	kg	kg	kg	kg	kg	kg	°C
VLE Jour	9	40	80	9	30	5	17.0	86.0	77.0	154.0	17.0	48.0	10.0	
VLE 30 min	60	200	400	20	30	30								
Autre seuil						150								850.00
Moy.	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h	24h
00:30	4.21	2.53	59.55	0.35	0.31	0.49	0.20	0.07	0.12	2.81	0.02	0.01	0.02	1144
01:00	3.56	4.31	49.18	0.34	0.33	0.48	0.17	0.08	0.21	2.38	0.02	0.02	0.02	1154
01:30	5.63	13.22	62.61	0.34	0.32	0.48	0.27	0.06	0.63	2.97	0.02	0.02	0.02	1168
02:00	6.91	10.74	61.09	0.33	0.32	0.46	0.32	0.06	0.50	2.87	0.02	0.02	0.02	1162
02:30	4.83	5.34	60.23	0.32	0.32	0.44	0.23	0.07	0.25	2.82	0.01	0.02	0.02	1160
03:00	5.71	12.21	55.50	0.29	0.32	0.40	0.27	0.06	0.58	2.62	0.01	0.02	0.02	1136
03:30	6.46	9.27	58.25	0.30	0.35	0.40	0.30	0.05	0.43	2.70	0.01	0.02	0.02	1121
04:00	5.33	10.41	55.36	0.29	0.32	0.39	0.25	0.05	0.49	2.62	0.01	0.01	0.02	1153
04:30	5.68	10.53	59.60	0.30	0.31	0.40	0.27	0.05	0.50	2.82	0.01	0.01	0.02	1161
05:00	5.06	8.73	55.64	0.29	0.29	0.38	0.24	0.05	0.41	2.64	0.01	0.01	0.02	1140
05:30	6.52	14.40	61.24	0.28	0.32	0.37	0.31	0.06	0.68	2.90	0.01	0.01	0.02	1146
06:00	5.61	7.91	56.23	0.29	0.30	0.38	0.26	0.05	0.37	2.62	0.01	0.01	0.02	1151
06:30	5.55	9.74	58.28	0.28	0.33	0.37	0.27	0.05	0.47	2.80	0.01	0.02	0.02	1149
07:00	4.60	5.86	65.44	0.28	0.37	0.38	0.21	0.07	0.27	3.00	0.01	0.02	0.02	1135
07:30	5.79	10.43	63.82	0.28	0.38	0.37	0.26	0.08	0.47	2.90	0.01	0.02	0.02	1124
08:00	5.18	7.13	62.78	0.36	0.35	0.34	0.23	0.04	0.32	2.83	0.02	0.02	0.02	1141
08:30	6.50	10.86	56.98	0.28	0.37	0.37	0.30	0.04	0.51	2.66	0.01	0.02	0.02	1164
09:00	5.84	4.74	61.09	0.29	0.36	0.38	0.27	0.05	0.22	2.86	0.01	0.02	0.02	1159
09:30	4.51	2.19	58.12	0.31	0.40	0.42	0.21	0.06	0.10	2.70	0.01	0.02	0.02	1145
10:00	5.50	8.36	53.55	0.33	0.39	0.46	0.26	0.05	0.39	2.53	0.02	0.02	0.02	1138
10:30	5.34	4.89	62.50	0.35	0.41	0.50	0.25	0.06	0.23	2.93	0.02	0.02	0.02	1162
11:00	5.23	6.04	56.44	0.36	0.41	0.50	0.24	0.05	0.28	2.64	0.02	0.02	0.02	1145
11:30	5.37	5.89	59.00	0.35	0.41	0.49	0.25	0.07	0.28	2.80	0.02	0.02	0.02	1169
12:00	4.87	3.58	57.09	0.36	0.42	0.51	0.22	0.06	0.16	2.62	0.02	0.02	0.02	1150
12:30	4.04	2.23	58.77	0.36	0.42	0.51	0.19	0.05	0.10	2.72	0.02	0.02	0.02	1149
13:00	4.46	5.93	57.04	0.36	0.43	0.51	0.21	0.04	0.27	2.64	0.02	0.02	0.02	1131
13:30	6.09	8.22	59.23	0.37	0.42	0.53	0.28	0.05	0.38	2.76	0.02	0.02	0.02	1176
14:00	6.89	8.48	56.62	0.43	0.48	0.63	0.31	0.04	0.38	2.52	0.02	0.02	0.03	1139
14:30	6.97	12.76	56.88	0.42	0.43	0.62	0.33	0.05	0.60	2.67	0.02	0.02	0.03	1163
15:00	6.13	8.30	58.43	0.42	0.44	0.61	0.29	0.05	0.39	2.76	0.02	0.02	0.03	1168
15:30	4.78	2.75	55.60	0.46	0.47	0.67	0.21	0.04	0.12	2.39	0.02	0.02	0.03	1143
16:00	4.47	6.57	59.45	0.43	0.44	0.62	0.21	0.05	0.30	2.75	0.02	0.02	0.03	1156
16:30	5.42	9.02	58.20	0.43	0.43	0.62	0.25	0.04	0.42	2.70	0.02			