

	mesures corrigées à 11% d'O2 -IC 95%									Flux massique									Process
Paramètre	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3	CO2	Hg	T2S
																			Foyer
Unité	mg/m³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	mg/Nm³	-	µg/Nm³	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	kg/h	-	g/h	°C
VLE 30 min		20	60	200	30	400	30	0											
VLE max	100	20			150														
VLE jour	45	9	9	40	5	80	30	0		86.00	17.00	17.00	77.00	10.00	154.00	48.00	0.00	0.00	
Seuils min																			850
00:30	1.78	0.29	4.08	5.09	0.00	59.51	0.68	1.58	0.00	0.06	0.01	0.14	0.17	0.00	2.04	0.02	1.33	0.0000	1091
01:00	2.08	0.27	5.09	8.56	0.00	65.11	0.71	1.93	0.00	0.07	0.01	0.18	0.31	0.00	2.34	0.03	1.64	0.0000	1114
01:30	1.14	0.27	6.69	11.01	0.00	57.36	0.52	1.04	0.00	0.04	0.01	0.24	0.39	0.00	2.03	0.02	0.87	0.0000	1095
02:00	0.69	0.26	5.24	7.42	0.04	65.70	0.63	0.60	0.00	0.02	0.01	0.18	0.26	0.00	2.32	0.02	0.50	0.0000	1111
02:30	1.01	0.25	5.33	8.66	0.01	61.28	0.60	0.89	0.00	0.04	0.01	0.20	0.32	0.00	2.26	0.02	0.75	0.0000	1138
03:00	2.19	0.25	5.23	10.29	0.00	61.10	0.47	2.08	0.00	0.08	0.01	0.19	0.38	0.00	2.25	0.02	1.74	0.0000	1123
03:30	1.17	0.25	5.09	8.22	0.00	60.43	0.71	1.09	0.00	0.04	0.01	0.18	0.30	0.00	2.19	0.03	0.91	0.0000	1133
04:00	1.20	0.26	5.08	7.05	0.00	64.25	0.58	1.06	0.00	0.04	0.01	0.18	0.25	0.00	2.30	0.02	0.89	0.0000	1120
04:30	0.71	0.26	5.40	9.23	0.00	59.75	0.51	0.65	0.00	0.03	0.01	0.19	0.33	0.00	2.15	0.02	0.54	0.0000	1124
05:00	1.16	0.26	5.39	9.74	0.00	61.01	0.74	1.02	0.00	0.04	0.01	0.19	0.35	0.00	2.20	0.03	0.84	0.0000	1119
05:30	0.42	0.11	5.11	8.18	0.00	60.82	0.51	3.80	0.00	0.02	0.00	0.19	0.31	0.00	2.28	0.02	3.23	0.0000	1133
06:00	0.61	0.00	4.15	5.49	0.00	61.01	0.56	6.00	0.00	0.02	0.00	0.16	0.21	0.00	2.33	0.02	5.19	0.0000	1133
06:30	0.95	0.00	4.16	5.87	0.00	63.22	0.52	6.10	0.00	0.04	0.00	0.16	0.23	0.00	2.43	0.02	5.27	0.0000	1140
07:00	1.17	0.01	4.71	8.16	0.00	61.73	0.52	6.14	0.00	0.05	0.00	0.18	0.32	0.00	2.42	0.02	5.36	0.0000	1138
07:30	0.93	0.01	5.06	8.11	0.00	63.78	0.52	6.04	0.00	0.04	0.00	0.20	0.32	0.00	2.52	0.02	5.40	0.0000	1132
08:00	1.22	0.01	4.68	7.60	0.01	60.56	0.49	5.90	0.00	0.05	0.00	0.18	0.30	0.00	2.38	0.02	5.34	0.0000	1098
08:30	1.69	0.02	5.15	9.28	0.01	66.11	0.53	6.02	0.00	0.07	0.00	0.21	0.37	0.00	2.65	0.02	5.50	0.0000	1116
09:00	2.37	0.02	5.01	9.55	0.02	61.36	0.53	6.05	0.00	0.10	0.00	0.20	0.38	0.00	2.47	0.02	5.53	0.0000	1100
09:30	2.42	0.04	6.69	18.14	0.00	56.25	0.51	6.10	0.00	0.10	0.00	0.26	0.71	0.00	2.21	0.02	5.40	0.0000	1103
10:00	0.61	0.02	3.67	4.87	0.00	64.94	0.50	6.23	0.00	0.02	0.00	0.15	0.19	0.00	2.58	0.02	5.43	0.0000	1135
10:30	1.44	0.02	4.18	17.32	0.00	60.60	0.43	6.44	0.00	0.06	0.00	0.17	0.70	0.00	2.44	0.02	5.49	0.0000	1149
11:00	1.59	0.06	5.73	14.54	0.00	62.70	0.47	6.38	0.00	0.07	0.00	0.24	0.60	0.00	2.60	0.02	5.67	0.0000	1136
11:30	0.37	0.05	3.66	6.14	0.00	56.99	0.46	6.37	0.00	0.01	0.00	0.14	0.24	0.00	2.24	0.02	5.38	0.0000	1150
12:00	0.68	0.08	4.63	7.79	0.00	64.15	0.45	6.48	0.00	0.03	0.00	0.19	0.32	0.00	2.64	0.02	5.63	0.0000	1168
12:30	27.77	1.49	4.64	10.09	0.00	67.90	0.46	6.40	0.00	1.16	0.06	0.19	0.42	0.00	2.83	0.02	5.73	0.0000	1136
13:00	16.03	0.08	5.24	11.40	0.00	69.73	0.49	6.40	0.00	0.67	0.00	0.22	0.48	0.00	2.93	0.02	5.76	0.0000	1134
13:30	2.80	0.12	4.55	6.92	0.00	61.64	0.55	4.81	0.00	0.12	0.01	0.19	0.28	0.00	2.54	0.02	4.36	0.0000	1140
14:00	1.93	0.26	6.01	9.79	0.00	60.05	0.66	1.80	0.00	0.08	0.01	0.23	0.38	0.00	2.35	0.03	1.64	0.0000	1124
14:30	3.40	0.25	3.65	2.79	0.00	62.96	0.59	3.29	0.00	0.14	0.01	0.15	0.11	0.00	2.54	0.02	3.00	0.0000	1149
15:00	3.95	0.23	4.88	7.73	0.00	60.98	0.60	3.84	0.00	0.16	0.01	0.20	0.31	0.00	2.48	0.02	3.51	0.0000	1145
15:30	2.17	0.22	6.81	7.96	0.00	62.36	0.57	2.09	0.00	0.09	0.01	0.27	0.32	0.00	2.51	0.02	1.91	0.0000	1115
16:00	4.50	0.24	5.32	7.71	0.00	58.92	0.72	4.34	0.00	0.18	0.01	0.21	0.31	0.00	2.38	0.03	3.96	0.0000	1132
16:30	2.05	0.24	5.24	5.51	0.00	66.44	0.63	1.92	0.00	0.08	0.01	0.21	0.22	0.00	2.60	0.02	1.75	0.0000	1108
17:00	2.45	0.24	6.08	12.52	0.00	58.55	0.61	2.36	0.00	0.10	0.01	0.24	0.50	0.00	2.32	0.02	2.11	0.0000	1103
17:30	2.10	0.09	4.74	8.80	0.00	58.62	0.45	4.60	0.00	0.08	0.00	0.18	0.34	0.00	2.24	0.02	3.94	0.0000	1097
18:00	0.96	0.00	4.29	8.16	0.00	63.34	0.43	6.19	0.00	0.04	0.00	0.17	0.32	0.00	2.45	0.02	5.29	0.0000	1113
18:30	1.07	0.00	4.48	7.99	0.00	59.73	0.43	6.29	0.00	0.04	0.00	0.17	0.31	0.00	2.32	0.02	5.34	0.0000	1113
19:00	2.04	0.00	4.18	6.17	0.00	65.07	0.49	6.36	0.00	0.08	0.00	0.17	0.25	0.00	2.62	0.02	5.51	0.0000	1139
19:30	1.67	0.00	4.82	8.44	0.00	60.39	0.44	6.32	0.00	0.07	0.00	0.20	0.35	0.00	2.48	0.02	5.60	0.0000	1147
20:00	1.17	0.00	5.09	9.11	0.00	63.50	0.50	6.25	0.00	0.05	0.00	0.20	0.37	0.00	2.55	0.02	5.54	0.0000	1121
20:30	1.92	0.16	4.90	7.36	0.00	59.82	0.30	3.54	0.00	0.08	0.01	0.19	0.29	0.00	2.37	0.01	3.15	0.0000	1120
21:00	2.37	0.24	5.36	8.68	0.00	62.45	0.19	2.30	0.00	0.09	0.01	0.21	0.34	0.00	2.48	0.01	2.05	0.0000	1117
21:30	2.18	0.23	5.25	8.61	0.00	58.95	0.14	2.10	0.00	0.09	0.01	0.21	0.34	0.00	2.33	0.01	1.87	0.0000	1109
22:00	1.68	0.23	4.83	5.33	0.00	63.91	0.16	1.59	0.00	0.06	0.01	0.19	0.20	0.00	2.46	0.01	1.41	0.0000	1123
22:30	3.19	0.22	5.15	7.76	0.00	61.60	0.21	3.15	0.00	0.13	0.01	0.21	0.32	0.00	2.53	0.01	2.86	0.0000	1146
23:00	3.55	0.22	5.05	8.01	0.00	61.01	0.17	3.49	0.00	0.15	0.01	0.21	0.33	0.00	2.50	0.01	3.18	0.0000	1153
23:30	29.80	3.96	5.02	12.62	0.01	71.72	0.19	20.74	0.67	1.22	0.16	0.20	0.52	0.00	2.93	0.01	18.80	0.0274	1135
00:00	3.09	0.34	6.20	10.64	0.00	63.12	0.14	2.99	0.00	0.13	0.01	0.25	0.43	0.00	2.56	0.01	2.73	0.0000	1127
Min	0,37	0,00	3,65	2,79	0,00	56,25	0,14	0,60	0,00	0,01	0,00	0,14	0,11	0,00	2,03	0,01	0,50	0,0000	1091
Max	29,80	3,96	6,81	18,14	0,04	71,72	0,74	20,74	0,67	1,22	0,16	0,27	0,71	0,00	2,93	0,03	18,80	0,0274	1168
Flux moyen (kg/h)	3,20	0,25	5,02	8,68	0,00	62,14	0,48	4,36	0,01	6,19	0,48	9,41	16,31	0,00	116,55	0,90	184,85	0,0274	1126
	CO	COT	HCL	SO2	POUSSIÈRES	NOx	NH3												

[illegible]

Commentaires :

Bon fonctionnement de l'UVE. Respect des normes européennes et françaises.